



Nebraska Public Power District

GENERAL OFFICE
P. O. BOX 499, COLUMBUS, NEBRASKA 68601
TELEPHONE (402) 564-8561

August 26, 1981

Director, Nuclear Reactor Regulation
Operating Reactors Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Attention: Mr. Thomas A. Ippolito, Chief

Dear Mr. Ippolito:

Subject: Proposed Changes to Technical Specifications
Cooper Nuclear Station
NRC Docket 50-298, DPR-46

Reference: 1) U.S. NRC Regulatory Guide 1.16, Revision 4,
August, 1975

In accordance with the provisions specified in 10CFR50.90, Nebraska Public Power District respectfully requests that the Cooper Nuclear Station Technical Specifications be amended to 1) delete the reporting requirements concerning secondary leak rate testing, and an item currently required to be covered in the Annual Operating Report dealing with Design Fatigue Usage, and 2) make a number of minor administrative changes.

The Standard Technical Specifications refer licensees to Reference 1, which contains neither of the aforementioned reporting requirements and states that it "provides an adequate basis for meeting the reporting requirements of Appendix A Technical Specifications." In addition, the reporting requirements that the District proposes to delete are adequately addressed to ensure proper review of the subject matter (see below).

Secondary Containment Leak Rate Testing

Section 4.7.C.1 ensures that the required secondary containment surveillance be conducted each refueling outage.

Annual Operating Report, Design Fatigue Usage

Section 6.6.2(G) requires that records be kept for the life of the plant and will be reviewed at least annually concerning certain locations of the Reactor Coolant Pressure Boundary. A comparison is made between the existing number of transient events recorded and the design specification quantity derived per the ASME Boiler and Pressure Vessel Code Section III.



Agg
1/1
w/chc-h:
\$1700.00

Mr. Thomas A. Ippolito
Page 2
August 26, 1981

The following is a brief description of the proposed administrative changes:

Additions to Table 3.2.B

A change is required to provide for the additional instrumentation installed per NUREG 0737, item II.K.3.15.

Additions to Table 3.7.1

A change is required to provide for the additional valves installed per NUREG 0737, item II.E.4.1.

Corrections to Tables 3.2.B and 4.2.B

A change is required to update and correct identification numbers (ID No.).

Deletion of a Note for Tables 4.2.A Through 4.2.F

A change is required to delete Note 11 from pages 77 and 81. Note 11 is no longer applicable.

Revise General Office Organization Chart, Page 236

A change is required to reflect current District organization. Based on this change, a title change must be made concerning SRAB membership, page 223.

Typographical Corrections


Changes are required to correct typographical errors found on the following pages: 80, 81, 83, 84, 103, 136, and 199.

The safety significance of these proposed changes has been reviewed by appropriate District personnel, and under 10CFR170, is adjudged to be a Class II Amendment. Accordingly, payment in the amount of \$1,200.00 is enclosed.

Should you have any questions or require additional information, please contact me.

In addition to three signed originals, 37 copies are also submitted for your use.

Sincerely,



Jay M. Pilant
Division Manager of
Licensing & Quality Assurance

JMP/kcw:rjd27/3
Enclosures

Mr. Thomas A. Ippolito
Page 3
August 26, 1981

STATE OF NEBRASKA)
)ss
PLATTE COUNTY)

Jay M. Pilant, being first duly sworn, deposes and says that he is an authorized representative of the Nebraska Public Power District, a public corporation and political subdivision of the State of Nebraska; that he is duly authorized to submit this request on behalf of Nebraska Public Power District; and that the statements in said application are true to the best of his knowledge and belief.

Jay M. Pilant
Jay M. Pilant

Subscribed in my presence and sworn to before me this 26th day
of August, 1981.

Colleen M. Kuta
NOTARY PUBLIC

My Commission expires August 4, 1985.

