

CONTROL BLOCK:

--	--	--	--	--	--	--

 ① (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONT

0	1
---	---

REPORT SOURCE

1	6	0	5	0	0	0	3	1	1	7	0	8	0	3	8	1	8	0	8	2	6	8	1	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

DOCKET NUMBER

EVENT DATE

REPORT DATE

On August 3, 1981, No. 22 CSD breaker tripped from an unidentified cause. There were

03 no indicating flags showing on the relays. No. 21 CSD breaker was closed manually.

04 | Action statement 3.8.2.1.a was entered at 1533 hours, August 3, 1981.

0 5 _____

06 _____

07 _____

0	E	
---	---	--

C 9		SYSTEM CODE E B		CAUSE CODE X		CAUSE SUBCODE Z		COMPONENT CODE C K T B R K				COMP SUBCODE A		VALVE SUBCODE Z	
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
17 LER RO REPORT NUMBER		EVENT YEAR 8 1		SEQUENTIAL REPORT NO 0 7 9		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO 0		ACTION TAKEN X		FUTURE ACTION X	
21		22		23		24		25		26		27		28	
EFFECT ON PLANT Z		SHUTDOWN METHOD Z		HOURS 0 0 0 0		ATTACHMENT SUBMITTED Y		NPRD-4 FORM SUB N		PRIME COMP SUPPLIER L		COMPONENT MANUFACTURER G 0 8 0		29	
29		30		31		32		33		34		35		36	

10 The cause of the breaker trip is still undetermined. It is being investigated.

1 1 The immediate corrective action was to manually close the No. 21 CSD breaker. At

1 2 | 1542 hours, August 3, 1981, action statement 3.8.2.1.a was terminated.

1	3	Previous similar occurrence: 81-71.
---	---	-------------------------------------

1 4

FACILITY STATUS				% POWER			OTHER STATUS (30)			METHOD OF DISCOVERY		DISCOVERY DESCRIPTION (32)	
1	5	E	(2B)	0	7	5	(29)	N/A			A	(31)	Loss of vital bus.
7	8	9		10	11	12	13				45	46	

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 2 33 2 34 NA

7 8 9 10 11

AMOUNT OF ACTIVITY (35)

NA

LOCATION OF RELEASE (36)

PERSONNEL EXPOSURES										
NUMBER		TYPE		DESCRIPTION						
1	7	0	0	0	37	2	38	NA		

PERSONNEL INJURIES		11	12	3	60
NUMBER		DESCRIPTION			
1	8	1	0	0	40 NA

8 9		11 12		80	
TYPE		DESCRIPTION			
1	9	2	42	NA	

7 8 9 10
PUBLICITY
ISSUED DESCRIPTION (45)
2 0 [N] (44) NA
8 9 10
NRC USE ONLY

PHONE 609-935-5100

NRC USE ONLY

017-028