

U.S. NUCLEAR REGULATORY COMMISSION  
LICENSEE EVENT REPORT

CCNTROL BLOCK / / / / / (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)  
 /0/1/ /V/A/N/A/S/1/ (2) /C/0/-/0/0/0/0/0/-/0/0/ (3) /4/1/1/1/1/ (4) / / / (5)  
 LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT  
 /0/1/ REPORT /L/ (6) /0/5/0/0/0/3/3/8/ (7) /0/8/0/4/8/1/ (8) /0/2/6/8/1/ (9)  
 SOURCE DOCKET NUMBER EVENT DATE REPORT DATE  
 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)  
 /0/2/ / On August 4, 1981, with Unit 1 at 25 percent power, the Channel III Feedwater /  
 /0/3/ / Flow Indicator for the "C" steam generator began spiking high periodically. The /  
 /0/4/ / channel was placed in a tripped condition within one hour; therefore, the health /  
 /0/5/ / and safety of the general public were not affected. This is reportable pursuant /  
 /0/6/ / to T.S. 3.3.1.1 and 6.9.1.9.b. /  
 /0/7/ / /  
 /0/8/ / /  
 SYSTEM CAUSE CAUSE COMP. VALVE  
 CODE CODE SUBCODE COMPONENT CODE SUBCODE SUBCODE  
 /0/9/ /I/A/ (11) /E/ (12) /G/ (13) /I/N/S/T/R/U/ (14) /Y/ (15) /Z/ (16)  
 LER/RO EVENT YEAR SEQUENTIAL OCCURRENCE REPORT REVISION  
 REPORT NO. NO. NO. CODE TYPE NO.  
 (17) NUMBER /8/1/ /-/ /0/6/6/ / \ / /0/3/ /L/ /-/ /0/  
 ACTION FUTURE EFFECT SHUTDOWN ATTACHMENT NPRD-4 PRIME COMP. COMPONENT  
 TAKEN ACTION ON PLANT METHOD HOURS SUBMITTED FORM SUB. SUPPLIER MANUFACTURER  
 /A/ (18) /Z/ (19) /Z/ (20) /Z/ (21) /0/0/0/0/ (22) /Y/ (23) /N/ (24) /N/ (25) /W/1/2/0/ (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

/1/0/ / The multiplier/divider/square root card for the steam generator 1C Feedwater Flow/  
 /1/1/ / Channel III failed causing the output of the card to periodically spike high. /  
 /1/2/ / The card was replaced and the loop was calibrated and returned to service. /  
 /1/3/ / /  
 /1/4/ / /

FACILITY METHOD OF  
 STATUS %POWER OTHER STATUS DISCOVERY DISCOVERY DESCRIPTION (32)  
 /1/5/ /C/ (28) /0/2/5/ (29) / NA / (30) /A/ (31) / Operator Observation /

ACTIVITY CONTENT  
 RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)  
 /1/6/ /Z/ (33) /Z/ (34) / NA / / NA /

PERSONNEL EXPOSURES  
 NUMBER TYPE DESCRIPTION (39)  
 /1/7/ /0/0/0/ (37) /Z/ (38) / NA /

PERSONNEL INJURIES  
 NUMBER DESCRIPTION (41)  
 /1/8/ /0/0/0/ (40) / NA /

LOSS OF OR DAMAGE TO FACILITY  
 TYPE DESCRIPTION (43)  
 /1/9/ /Z/ (42) / NA /

PUBLICITY  
 ISSUED DESCRIPTION (45) 8109080177 810826  
 /2/0/ /N/ (44) / NA / PDR ADOCK 05000338 PDR  
 NRC USE ONLY  
 / / / / / / / / / / /

NAME OF PREPARER W. R. CARTWRIGHT PHONE (703) 894-5151