

## LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 NCMGS1 200-00000-00 341111 4 5

LICENSEE CODE LICENSE NUMBER LICENSE TYPE

01 L505000369 7072881 8082481 9

REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 While in Mode 5, during the performance of a periodic functional test of the re-

03 actor protective system, the Channel 4 overtemperature Delta T instrumentation

04 was found to be out of calibration and subsequently declared inoperable per T.S.

05 3.3.1 which is reportable pursuant to T.S. 6.9.1.13(b). Since failures of this

06 nature are provided for in the design of the redundant protective channels, the

07 incident did not restrict the functional capability of the reactor protective

08 system or affect the health and safety of the public.

09

11 IA 12 E 13 E 14 XXXXXX 15 Z 16 Z

SYSTEM CODE CAUSE CODE CAUSE SUCCESS CODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE

17 81 18 125 19 03 20 L 21 0

EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.

22 AZ 23 Z 24 0000 25 N 26 N 27 L 28 W120

ACTION TAKEN ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NRC FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 29

10 The cause was determined to be a faulty card in the overtemperature Delta T sol-

11 id state circuitry. Channel 4 was placed in the tripped condition (2 out of 3

12 coincidence logic vice normal 2 out of 4 coincidence logic), a replacement card

13 installed, and channel functionality verified. The channel was declared oper-

14 able on August 2, 1981.

15 x 0000 30 B 31 Periodic Functional Test 32

FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

16 Z 33 Z 34 N/A 35 N/A 36 N/A

ACTIVITY CONTENT RELEASED OR RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

17 0000 37 Z 38 N/A

PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

18 0000 40 N/A

PERSONNEL INJURIES NUMBER DESCRIPTION

19 Z 42 N/A

LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

20 N 44 N/A

PUBLICITY ISSUED DESCRIPTION

NAME OF PREPARER Phillip B. Nardoci PHONE: (704) 373-7432

NRC USE ONLY