

CONTROL BLOCK: 

--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
---	---

REPORT SOURCE

L	6	0	5	0	0	0	3	6	6	7	0	8	1	2	0	1	8	0	8	2	5	8	1	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 While operating at 87% power the HCU accumulator low pressure alarm was received for  
0 3 control rod 26-47. Tech. Specs. section 3.1.3.5 requires actuation at 955 + 15 psi.  
0 4 Operations personnel were dispatched to recharge this accumulator. This is a re-  
0 5 petitive occurrence (Ref. LER 50-366/1981-040). There was no effect on the public  
0 6 health or safety.  
0 7  
0 8

0	9	SYSTEM CODE		R	B	CAUSE CODE	X	CAUSE SUBCODE	Z	COMPONENT CODE						Z	Z	Z	Z	Z	Z	COMP. SUBCODE	Z	VALVE SUBCODE	Z						
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32						
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.		ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOJRS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER			
17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	
X	1	Z	1		0	7	5	/	0	3	L		0	X		Z		Z			0	0	0	0	Y	Y	Z	Z	9	9	9

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Control Rod 26-47's accumulator pressure had bled down to approximately 960 psid.

1 1 Operations personnel recharged accumulator and returned this accumulator to operable

1 2 status at 0820 8-12-81.

1 3

1 4

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION				
1	5	E	28	0	8	7	29	N/A	B	31	Operator Observation	32
ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE						
1	6	Z	33	Z	34	N/A	35	N/A	36			
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION						
1	7	0	0	0	37	Z	38	N/A	39			
PERSONNEL INJURIES		NUMBER		DESCRIPTION								
1	8	0	0	40		N/A	41					
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION								
1	9	Z	42		N/A	43						

8109080226 810825  
PDR ADOCK 05000366  
S PDR

NRC USE ONLY

S. X. Baxley, Supt. Operations

912-367-7851

NAME OF PREPARER

PHONE

LER #: 50-366/1981-075  
Licensee: Georgia Power Company  
Facility Name: Edwin I. Hatch  
Docket No. 50-366

Narrative Report  
for LER 50-366/1981-075

While operating at 87% power on 8-12-81 at 0608 CDST, the accumulator low pressure alarm was received for control rod 26-47. Personnel were sent to recharge the accumulator. Accumulator pressure had decreased to approximately 960 psig. The accumulator was recharged to 1100 psig at 0820 CDST 8-12-81. Shift personnel could not determine the cause of pressure reduction for this accumulator. Control rod 26-47 was returned to operable status following recharging of accumulator.