

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	2	7	0	G	-	9	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5		
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT		58

CON'T

REPORT SOURCE 0 1 L 6 0 5 0 - 0 3 2 4 7 0 8 1 7 8 1 6 0 8 3 1 8 1 9
7 8 60 61 68 69 74 75 80
DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During plant operation, routine surveillance revealed that primary containment
0 3 | atmospheric oxygen analyzer, 2-CAC-AF-1263-2, Model No. F3M3, was giving indication
0 4 | of drywell oxygen concentration that was 1.5% higher than the indication shown by the
0 5 | other primary containment atmospheric oxygen analyzer, 2-CAC-AF-1259-2. This event
0 6 | did not affect the health and safety of the public.

0 7 _____
 0 8 _____ Technical Specification 3.3.5.3, 3.6.6.4, 6.9.1.9b
 1 9 _____ 80

SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE			
S	E	E	E	I	N	S	T	R	U	Y	Z				
9	10	11	12	13					18	19	20				
EVENT YEAR		SEQUENTIAL REPT. NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.							
8	1			0	8	9	/	0	3	L	-	0			
21	22	23	24	25	26	27	28	29	30	31	32				
ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD		HOURS	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER				
E	X	Z	Z		0	0	0	0	N	Y	N	B	1	3	5
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | A calibration check of both analyzers revealed that the 1259-2 analyzer was operating
1 1 | properly and the 1263-2 analyzer was out of calibration, apparently due to instrument
1 2 | drift. The analyzer was recalibrated and was returned to service. Due to a history
1 3 | of similar instrument drift and moisture-related problems, a plant modification has
1 4 | been developed to replace these analyzers with others of a more reliable design.

1 5 F 28 0 8 2 29 NA 30 31 Operator Surveillance 32 33 Z 34 NA 35 36 NA

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	2	(38)	NA	(39)

PERSONNEL INJURIES		DESCRIPTION (41)	
NUMBER			
1 8	0 0 0 (40)	NA	

1 9		Z (42)		NA
LOSS OF OR DAMAGE TO FACILITY (43)				
TYPE		DESCRIPTION		

7 8 9 10 PUBLICITY (45) 8109090403 810831
 ISSUED DESCRIPTION (44) PDR ADOCK 05000324 NRC USE ONLY
 2 0 [N] NA S PDR 68 69 80

NAME OF PREPARER M. J. Pastva, Jr.

PHONE: (919) 457-9521