

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION

01 | ALJMF2 | 200-0000-00 | 341111 | 4 | 5
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

REPORT SOURCE | L60500364 | 7073181 | 8083181 | 9
DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 | At 0430 on 7/31/81, the containment atmosphere radioactivity monitoring system (R-11)
03 | was declared inoperable due to filter paper not advancing. Tech. Spec. 3.4.7.1 requires
04 | R-11 to be operable. Tech. Spec. 3.4.7.1 action statement requirements were met. Health/
05 | safety of the public was not affected. A similar occurrence was reported in Unit 2 LER
06 | 81-010/03L-0.

07 |
08 |
09 |

SYSTEM CODE BB 11 | CAUSE CODE E 12 | CAUSE SUBCODE B 13 | COMPONENT CODE FILTER 14 | COMP. SUBCODE Z 15 | VALVE SUBCODE Z 16
LER/RO REPORT NUMBER 81 | EVENT YEAR 81 | SEQUENTIAL REPORT NO. 032 | OCCURRENCE CODE 03 | REPORT TYPE L | REVISION NO. 0
ACTION TAKEN E 18 | FUTURE ACTION H 19 | EFFECT ON PLANT Z 20 | SHUTDOWN METHOD Z 21 | HOURS 0000 | ATTACHMENT SUBMITTED 11 23 | NPR-4 FORM SUB. N 24 | PRIME COMP. SUPPLIER N 25 | COMPONENT MANUFACTURER C518 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 | The event was caused by the filter paper spool plates slipping. The plates were tightened
11 | and R-11 was returned to service at 0925 on 7/31/81. A memorandum concerning proper
12 | installation of paper in R-11 & R-12 was sent to the Health Physics Foreman and to all
13 | involved technicians.

14 |
15 | FACILITY STATUS E 28 | % POWER 095 29 | OTHER STATUS NA 30 | METHOD OF DISCOVERY A 31 | DISCOVERY DESCRIPTION Operator Observation 32

16 | ACTIVITY CONTENT RELEASED OF RELEASE Z 33 | Z 34 | AMOUNT OF ACTIVITY NA 35 | LOCATION OF RELEASE NA 36

17 | PERSONNEL EXPOSURES NUMBER 000 37 | TYPE Z 38 | DESCRIPTION NA 39

18 | PERSONNEL INJURIES NUMBER 000 40 | DESCRIPTION NA 41

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 | DESCRIPTION NA 43

20 | PUBLICATION ISSUED N 44 | DESCRIPTION NA 45

8109090437 810831
 PDR ADOCK 05000364
 S PDR

NRC USE ONLY

NAME OF PREPARER W. G. Hairston, III

PHONE: (205) 899-5156