



# VERMONT YANKEE NUCLEAR POWER CORPORATION

SEVENTY SEVEN GROVE STREET  
RUTLAND, VERMONT 05701

2.C.2.1  
REPLY TO FVY 81-127  
ENGINEERING OFFICE  
1671 WORCESTER ROAD  
FRAMINGHAM, MASSACHUSETTS 01701  
TELEPHONE 617 872 8100

September 2, 1981

United States Nuclear Regulatory Commission  
Washington, D. C. 20555

Attention: Office of Nuclear Reactor Regulation  
Mr. D. G. Eisenhut, Director

References: (a) License No. DPR-28 (Docket No. 50-271)  
(b) Letter, VYNPC to USNRC, FVY 81-113, dated  
August 7, 1981



Subject: Response to NUREG-0737, Item III.D.3.4, Control Room Habitability

Dear Sir:

Reference (b) was submitted in response to the subject NUREG item and included a description of protective respiratory equipment being proposed for use in meeting the requirements of that item. In Reference(b), we stated that the oxygen supply cylinders for the Bio Pak units could be changed while the units were in use. It has come to our attention that, although such action is possible under extreme circumstances, it is not recommended by the manufacturer.

Vermont Yankee intends to comply with the manufacturer's recommendations regarding the use of this equipment. As stated in Reference(b), a sufficient number of Bio Pak units will be strategically located to equip the operating crew in the event that their use is required.

We trust the information supplied above is satisfactory; however, should you have any questions, please contact us.

Very truly yours,

VERMONT YANKEE NUCLEAR POWER CORPORATION

R. L. Smith  
Licensing Engineer

RLS/saw

A-44  
Silo