

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 ALJMF1200-00000-0034111145

REPORT SOURCE L605000348708098130904819

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 At 0200 on 8/9/81, the average containment air temperature increased to 120.0°F. Tech.

03 Spec. 3.6.1.5 requires the average containment air temperature to be less than or equal

04 to 120°F. Tech. Spec. 3.6.1.5 action statement requirements were met. Health/safety

05 of the public was not affected. A similar occurrence was reported in LER 81-050/03L-0.

06

07

08

09 AA11 C12 Z13 ZZZZZZ14 Z15 Z16

17 81 057 03 L 0

X18 Z19 Z20 Z21 000 N22 N23 N24 Z25 Z2627

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 The containment ventilation system was realigned and the average containment air

11 temperature returned to a value within the Tech. Spec. limit at 0415 on 8/9/81.

12

13

14

15 E28 10029 NA A31 Operator Observation

16 Z33 Z34 NA NA

17 00037 Z38 NA

18 00040 NA

19 Z42 NA

20 Z44 S

8109110185 810904
PDR ADOCK 05000348
S PDR

NRC USE ONLY