



ARKANSAS POWER & LIGHT COMPANY
POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

September 10, 1981

1CAN098104

Director of Nuclear Reactor Regulation
ATTN: Mr. J. F. Stolz, Chief
Light Water Reactors Branch #1
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555



SUBJECT: Arkansas Nuclear One - Unit 1
Docket No. 50-313
License No. DPR-51
Purging and Venting of Containment
(File: 1511.1)

Gentlemen:

We have reviewed the sample Technical Specifications (TSs) included in your July 15, 1981 letter against our existing TSs as requested. As a result of this review we have concluded that our current TSs meet the intent of the sample TSs either through our response to the surveillance part of your July 15, 1981 letter, the existing TS requirements, or because the sample TSs do not apply as our purge valves remain closed during operation.

Very truly yours,

David C. Trimble
for David C. Trimble,
Manager, Licensing

DCT:MCS:kb
MCS

A094
5/10

0109150110 940910
PDR ADOCK 05000313
PDR

MEMBER MIDDLE SOUTH UTILITIES SYSTEM