

CONTROL BLOCK: | | | | | | | 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
---	---

REPORT SOURCE

L	6	1	0	5	0	0	0	2	5	5	7	0	8	2	1	8	1	8	0	9	0	4	8	1	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

DOCKET NUMBER

EVENT DATE

REPORT DATE

02 | During resin sluicing per SOP 2 B 6.2.5 on the T52 demineralizer, an alarm
03 | was received from RIA 2318 (gross gas monitor on the stack). Inspection of
04 | the RIA 2318 tracing indicated a release had occurred through the stack.
05 | Abnormally high pressure resulting from the sluicing operation exceeded the
06 | set point of relief valve RV1111 which opened momentarily and released some
07 | waste gas to the stack. This was in violation of TS 3.9.17 and is report-
08 | able under TS 6.9.2.a(2).

6 9		SYSTEM CODE M B 11		CAUSE CODE D 12		CAUSE SUBCODE Z 13		COMPONENT CODE Z Z Z Z Z Z 14				COMP. SUBCODE Z 15		VALVE SUBCODE Z 16	
7 8		9 10		11 12		13 14		15 16				17 18		19 20	
17 LER RO REPORT NUMBER		EVENT YEAR 8 1		SEQUENTIAL REPORT N° 0 3		OCCURRENCE CODE 0 1		REPORT TYPE T		REVISION NO. 0					
21 22		23 24		25 26		27 28		29 30		31 32					
ACTION TAKEN G 18 F 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22		ATTACHMENT SUBMITTED N 23		NPRD-4 FORM SUB N 24		PRIME COMP. SUPPLIER Z 25		COMPONENT MANUFACTURER Z 9 9 9 26	
33 34		35 36		37 38		39 40		41 42		43 44		45 46		47 48	

1 0 An inadequate procedure was determined to be the root cause. Procedure SOP

1 1 2 B 6.2.5 is to be changed to include monitoring of the system pressure

1 2 during the sluicing operation. Modifications such as installation of a

1 3 pressure regulator are being considered to prevent recurrence.

1	4													
7	8	9												
FACILITY STATUS			% POWER			OTHER STATUS (30)			METHOD OF DISCOVERY			DISCOVERY DESCRIPTION (32)		
1	5	E	(28)	0	9	5	(29)	NA			A	(31)	Operator Observation	
7	8	9	10	11	12	13	14	15	16	17	18	19	20	
ACTIVITY CONTENT			RELEASED OR RELEASE			AMOUNT OF ACTIVITY (35)			LOCATION OF RELEASE (36)					
1	6	G	(33)	M	(34)	8.36 Curies			Stack					
7	8	9	10	11	12	13	14	15	16	17	18	19	20	
PERSONNEL EXPOSURES			NUMBER			TYPE			DESCRIPTION (39)					
1	7	0	0	0	(37)	Z	(38)	NA						
7	8	9	10	11	12	13	14	15	16	17	18	19	20	
PERSONNEL INJURIES			NUMBER			DESCRIPTION (41)								
1	8	0	0	0	(40)	NA								
7	8	9	10	11	12	13	14	15	16	17	18	19	20	
LOSS OF OR DAMAGE TO FACILITY			TYPE			DESCRIPTION (43)								
1	9	Z	(42)	NA										
7	8	9	10	11	12	13	14	15	16	17	18	19	20	
PUBLICITY			ISSUED			DESCRIPTION (45)								
2	0	N	(44)	NA										
7	8	9	10	11	12	13	14	15	16	17	18	19	20	
										NRC USE ONLY				
7	8	9	10	11	12	13	14	15	16	17	18	19	20	