

LICENSEE EVENT REPORT

CONTROL BLOCK

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 N E C P R 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 LICENSE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 58

CONT

01 REPORT SOURCE L 6 0 5 0 0 0 2 9 8 7 0 7 2 3 8 1 8 U 8 2 5 8 1 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During performance of Surveillance Procedure 6.3.12.1 to prove operability of #1 DG
03 prior to making "B" loop of containment cooling subsystem inoperable for maintenance,
04 a fuel supply hose developed a leak. #1 DG was shut down and declared inoperable.
05 Surveillance procedures per RTS 4.5.F.1 were commenced. This event is not repetitive.
06 There were no adverse effects on the public health and safety.
07
08

09
7 8 9

09 SYSTEM CODE E E 11 CAUSE CODE E 12 CAUSE SUBCODE B 13 COMPONENT CODE E N G I N E 14 COMP SUBCODE Z 15 VALVE SUBCODE Z 16
7 8 9 10 11 12 13 14 15 16
17 LER/RO REPORT NUMBER 8 1 21 22 23 24 25 26 27 28 29 30 31 32
18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB PRIME COMP SUPPLIER COMPONENT MANUFACTURER
A 18 F 19 Z 20 Z 21 0 0 0 0 N 23 24 25 26 27 28 29 30 31 32

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Fuel supply hose (Part #2-01H-003-042) developed a leak due to excessive localized
11 flexure and vibration. Fuel supply hose was replaced restoring #1 DG to normal oper-
12 ability. Fuel hose will be rerouted during outage to alleviate excessive flexure.
13
14

15
7 8 9

15 FACILITY STATUS E 28 0 9 5 29 NA 30 METHOD OF DISCOVERY B 31 Surveillance Testing 32
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

16 Z 33 Z 34 NA 35 LOCATION OF RELEASE NA 36
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

17 0 0 0 37 Z 38 NA 39
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

18 0 0 0 40 NA 41
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

19 Z 42 NA 43
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

20 N 44 NA 45
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

81091501 2 810825
PDR ADDOCK 05000298
S PDR

NRC USE ONLY

NAME OF PREPARER Scott S. Freborg

PHONE 402-825-3811