

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

REPORT
SOURCE

REPORT SOURCE L 6 0 5 0 0 0 2 6 7 7 0 7 2 8 8 1 8 0 8 2 6 8 1 9

7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

On July 28, 1981, with the plant operating at 30% power and 83 MWe, the emergency feedwater supply to Loop 1 helium circulator water turbines was isolated to repair leaking relief valves. This is a degraded mode of LCO 4.2.2(a) and is reportable per Fort St. Vrain Technical Specification AC 7.5.2(b)2. No accompanying occurrence. No effect on public health and safety. Similar reports RO 81-019, RO 80-015, and RO 80-023.

SYSTEM CODE H H 11		CAUSE CODE E 12		CAUSE SUBCODE B 13		COMPONENT CODE V A L V E X 14		COMP. SUBCODE X 15		VALVE SUBCODE B 16	
7 8		9 10		11		12 13 14 15 16 17		18 19		20	
17		EVENT YEAR 8 1		SEQUENTIAL REPORT NO. 0 4 6		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO. 0	
18		21 22		23 24 25 26		27 28 29		30 31		32	
ACTION TAKEN B 18		FUTURE ACTION Z 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22		ATTACHMENT SUBMITTED Y 23	
33 34		35 36		37 38 39 40		41 42		43 44		45 46 47	
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)											

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 1 J Relief valve leakage downstream of pressure control valve necessitated isolation for
1 1 repair. The 2" 1900 series Consolidated Safety Relief valves were removed, rebuilt,
1 2 bench tested, and re-installed. Emergency feedwater to Loop 1 was restored to ser-
1 3 vice.
1 4

FACILITY STATUS (28) 1 5 E' 28 0 3 0 29 N/A 44

% POWER 10 12 13

OTHER STATUS (30)

METHOD OF DISCOVERY (31) A 31 Operator Observation 45 46 80

DISCOVERY DESCRIPTION (32)

ACTIVITY CONTENT

RELEASED OF RELEASE (33) 1 6 Z 33 10 11 12 13

AMOUNT OF ACTIVITY (35) 44

LOCATION OF RELEASE (36) 45 N/A 80

PERSONNEL EXPOSURES

NUMBER TYPE DESCRIPTION (39) 1 7 0 0 0 37 Z 38 N/A 11 12 13 80

PERSONNEL INJURIES

NUMBER DESCRIPTION (41) 1 8 0 0 0 40 N/A 11 12 80

LOSS OF OR DAMAGE TO FACILITY

TYPE DESCRIPTION (43) 1 9 Z 42 N/A 10 80

PUBLICITY

ISSUED DESCRIPTION (45) 2 0 N 44 N/A 10 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

NRC USE ONLY

NRC USE ONLY