



435 Sixth Avenue
Pittsburgh, Pa.
15219

(412) 456-6000

September 16, 1981

Director of Nuclear Reactor Regulation
United States Nuclear Regulatory Commission
Attn: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing
Washington, DC 20555



Reference: Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
Proposed Change Request No. 67 to Operating License

Gentlemen:

Enclosed are three (3) originals and thirty-seven (37) copies of proposed Change Request No. 67 to the Beaver Valley Power Station Technical Specifications Appendix A. This proposal requests that Table 4.3-7 ACCIDENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS as added by Amendment No. 39 be modified to include the PORV Control Pressure Channels (PT-RC-444,445).

Safety Evaluation

The purpose of this change is to include the PORV Control Pressure Channels (PT-RC-444,445) in the channel calibration requirements of Table 4.3-7 which had been omitted from Amendment No. 39.

The isolation of the PORV to comply with Technical Specification 3.4.11a represents a potential challenge on the safety valves. Since the PORV's contain a protection grade interlock for closure, if plant pressure dropped below 2,000 psig, we feel that continued operation with a PORV in service is in the best interest of overall plant safety. We have no reason to suspect the control pressure channels calibration since indication on all seven (7) RCS pressure instruments are within a 25 psig span.

The OSC and ORC have reviewed this proposed Change Request No. 67 and have determined that there are no unreviewed safety implications associated with this change and that this change does not constitute an unreviewed safety question.

Since this change was omitted from Amendment No. 39, we have determined that no fee is required.

Very truly yours,

J. J. Carey
Vice President, Nuclear

A001
S
1/1

8109220486 810916
PDR ADOCK 0500C334
P PDR

Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
Proposed Change Request No. 67 to Operating License
Page 2

cc: Mr. D. A. Beckman, Resident Inspector
U.S. Nuclear Regulatory Commission
Beaver Valley Power Station
Shippingport, PA 15077

U.S. Nuclear Regulatory Commission
c/o Document Management Branch
Washington, DC 20555

COMMONWEALTH OF PENNSYLVANIA)

} SS:

COUNTY OF BEAVER

On this 16th day of September, 1981, before me, Judith D. Anthony, a Notary Public in and for said Commonwealth and County, personally appeared J. J. Carey, who being duly sworn, deposed, and said that (1) he is Vice President of Duquesne Light, (2) he is duly authorized to execute and file the foregoing Submittal on behalf of said Company, and (3) the statements set forth in the Submittal are true and correct to the best of his knowledge, information and belief.

Judith D. Anthony
Notary Public

JUDITH D. ANTHONY, Notary Public
Shippingport Borough, Beaver Co., Pa.
My Commission Expires Dec. 12, 1983