

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 A L J M F 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

REPORT SOURCE L 6 0 5 0 0 0 3 4 8 7 0 8 1 2 8 1 3 0 9 0 9 8 1 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 At 1700 on 8/12/81, the "A" Loop Tavg. protection channel (412D) was declared inoperable

0 3 when the associated temperature indicator (TI-412D) failed low. Tech. Spec. 3.3.1.1,

0 4 in part, requires protection channel 412D to be operable. Tech. Spec. 3.3.1.1 action

0 5 statement requirements were met. Health/safety of the public was not affected.

0 6

0 7

0 8

SYSTEM CODE I A 11 CAUSE CODE E 12 CAUSE SUBCODE E 13 COMPONENT CODE I N S T R U 14 COMP. SUBCODE E 15 VALVE SUBCODE Z 16

EVENT YEAR 8 1 21 22 SEQUENTIAL REPORT NO. 0 6 0 27 OCCURRENCE CODE 0 3 28 29 REPORT TYPE L 30 REVISION NO. 0 32

LER/RO REPORT NUMBER 17 ACTION TAKEN A 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPRO-4 FORM SUB. N 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER W 1 2 0 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 This event was caused by the failure of a lead-lag card. The card was replaced and

1 1 following calibration, protection channel 412D was returned to service at 0225 on

1 2 8/13/81.

1 3

1 4

FACILITY STATUS E 28 % POWER 1 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Operator Observation 32

ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39

PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41

LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

PUBLICITY ISSUED N 44 DESCRIPTION NA 45

8109220525 810909
PDR ADOCK 05000348
S PDR

NRC USE ONLY

NAME OF PREPARER W. G. Hairston, III PHONE: (205)899-5156