

USNRC REGION II  
SOUTH CAROLINA ELECTRIC & GAS COMPANY NTA, GEORGIA

POST OFFICE BOX 764

COLUMBIA, SOUTH CAROLINA 29218

T. C. NICHOLS, JR.  
VICE PRESIDENT AND GROUP EXECUTIVE  
NUCLEAR OPERATIONS

September 2, 1981



Mr. James P. O'Reilly, Director  
U.S. Nuclear Regulatory Commission  
Region II, Suite 3100  
101 Marietta Street  
Atlanta, Georgia 30303

Subject: V.C. Summer Nuclear Station  
Docket No. 50/395  
I&E Bulletin 81-03

Dear Mr. O'Reilly:

This is submitted as a followup to our letter of July 9, 1981 and is in response to IEB 81-03.

We have completed our inspection of representative portions of potentially affected safety and fire systems. There is no indication of any current or past infestation. No living organisms or debris was found in any of the systems.

An inspection was also conducted of some non-safety systems cooled by the Monticello Reservoir. All inspected systems and components were negative except the main condenser, where a very limited infestation was found, i.e., less than one individual per square meter.

No further actions are planned at this time; however, SCE&G will implement a program of flow monitoring on safety-related system components by the date of commercial operation. Because of the limited infestation discovered in the main condenser, this program will be supplemented by periodic visual inspections.

I declare the statements and matters set forth herein are true and correct to the best of my knowledge, information, and belief.

Very truly yours,

T.C. Nichols, Jr.

FJL/TCN/bsg

cc: See Page 2

IEB  
3  
111

Mr. James P. O'Reilly  
I&E Bulletin 81-03

Page 2 of 2

cc: V.C. Summer  
G.H. Fischer  
H.N. Cyrus  
T.C. Nichols, Jr.  
O.W. Dixon, Jr.  
D.A. Nauman  
W.A. Williams, Jr.  
R.B. Clary  
O.S. Bradham  
A.R. Ketchum  
A.A. Smith  
H. Radin  
M.N. Browne  
H.E. Yocom  
B.A. Bursey  
J.L. Skolds  
J.B. Knotts, Jr.  
Dr. J.C. Ruoff  
I&E Washington  
NPCF  
File