



**Florida  
Power**  
CORPORATION

August 31, 1981  
File: 3-0-3-a-4

Mr. J. P. O'Reilly  
Director  
U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Suite 3100  
101 Marietta Street  
Atlanta, GA 30303



Subject: Crystal River Unit 3  
Docket No. 50-302  
Operating License No. DPR-72  
I.E. Bulletin 81-02 Supplement: FAILURE OF GATE TYPE VALVES  
TO CLOSE AGAINST DIFFERENTIAL PRESSURE

Dear Mr. O'Reilly:

In response to the subject Bulletin Supplement, we have reviewed our master valve list of all suppliers and/or manufacturers of safety-related valves and determined that none of the affected Westinghouse-EMD (3, 4, 6, 8, 10, 12, 14, 16 and 18 inch nominal size motor operated gate valves) valves are installed or maintained as spares at CR-3. Therefore, no additional information will be provided.

As you requested, the manhours expended on this bulletin supplement in conduct of review for and preparation of this response is 8 hours.

Please contact this office if you require any additional discussion concerning our response.

Very truly yours,

*William A. Cross*

William A. Cross  
Manager  
Nuclear Licensing

Lobo(8/31)C4-3

cc: Director  
Office of Inspection and Enforcement  
Division of Reactor Operations Inspection  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

IEI/  
S  
1/1

STATE OF FLORIDA

COUNTY OF PINELLAS

W. A. CROSS states that he is the Manager, Nuclear Licensing, Nuclear Support Services, of Florida Power Corporation; that he is authorized on the part of said company to sign and file with the Nuclear Regulatory Commission the information attached hereto; and that all such statements made and matters set forth therein are true and correct to the best of his knowledge, information, and belief.

William A. Cross  
William A. Cross

Subscribed and sworn to before me, a Notary Public in and for the State and County above named, this 31st day of August 1981.

Margaret A. Chisamore  
Notary Public

Notary Public, State of Florida at Large,

My Commission Expires: May 29, 1984