

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

R. H. LEASBURG
VICE PRESIDENT
NUCLEAR OPERATIONS

SEP 18 1981
September 14, 1981

Mr. James P. O'Reilly, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Serial No. 465
PSE&C/RHW:lmf
Docket Nos. 50-338
50-339

License Nos. NPF-4
NPF-7

Dear Mr. O'Reilly:

I. E. Bulletin No. 80-11, Masonry Wall Design
North Anna Power Station - Units 1 & 2

Enclosed is our final report on I. E. Bulletin No. 80-11 activities at North Anna Power Station. This report provides the results of the masonry wall reevaluation program and provides documentation updating our previous submittals. Rather than being comprehensive and resubmitting information previously provided, this report contains a summary of the masonry wall review program and references our previous submittals where more detailed information has been provided.


In summary, the analysis results of the masonry wall reevaluation program for North Anna show that 37 walls were acceptable, two walls were acceptable after equipment was removed from the wall, 16 walls were modified, and 15 walls were not acceptable. All of the walls found not to meet the reevaluation criteria required by IE Bulletin 80-11 are located in the Fuel Building. Failure of these walls under extreme seismic or tornado loading would not jeopardize any safety-related equipment as covered by the Station Technical Specifications limiting conditions for operation. The analysis results for the 15 Fuel Building walls were submitted to the NRC in Licensee Event Report No. LER 81-062/03L-0 by our letter of August 20, 1981, Serial No. N-81-142. Our future correspondence on this subject will be in response to the LER rather than I.E. Bulletin 80-11.

IE11
S
1/0

8109240384 810914
PDR ADOCK 05000338
Q PDR

Should you have any questions or require additional information,
please contact us.

Very truly yours,

A handwritten signature in dark ink, appearing to read 'R. H. Leasburg', written in a cursive style.

R. H. Leasburg

Enclosure

cc: Mr. Victor Stello, Director
Office of Inspection & Enforcement

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation