



Carolina Power & Light Company

August 24, 1981

81 AUG 28 AB 3

File: NG-3513(B)

Serial No.: NO-81-1342

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Region II, Suite 3100
101 Marietta Street N.W.
Atlanta, GA 30303



BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 & 2
LICENSE NOS. DPR-71 AND DPR-62
DOCKET NOS. 50-325 AND 50-324
FINAL RESPONSE TO IE BULLETIN 80-15

Dear Mr. O'Reilly:

As committed to in our letter on November 6, 1980, the Brunswick Steam Electric Plant successfully completed a test of the Emergency Notification System (ENS) on June 13, 1981. This test consisted of simulating a loss of off-site power and verifying that the site emergency diesel generators supplied power to the ENS. The completion of this test fulfills the requirements of IE Bulletin 80-15.

Very truly yours,

B. J. Furr
Vice President
Nuclear Operations

RMP/cr (L#2)

cc: Mr. V. Stello, Jr.

IE11
3
1/0

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8109240457 DOC. DATE: 81/09/22 NOTARIZED: NO
 FACIL: 70-1308 Morris Operations, General Electric Co.,
 72-0001 Morris Operations, General Electric Co.,
 AUTH. NAME AUTHDR AFFILIATION
 ROTHSCHILD, M.U. Operations & Administrative Division
 BACHMAN, R.G. Office of the Executive Legal Director
 RECIP. NAME RECIPIENT AFFILIATION
 Atomic Safety and Licensing Board Panel

DOCKET #
 07001308
 07200001

SUBJECT: Answer supporting applicant 810828 motion for summary disposition of all contentions & ASLB Question 1. No genuine issue of matl fact exists re all contentions. Issues raised by ASLB Question 1 resolved by 10CFR72.

DISTRIBUTION CODE: DS07S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 40+110
 TITLE: ELD Filings (Non-Antitrust)

NOTES:

ACTION:	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTTR	ENCL		LTTR	ENCL
ACTION:	BC	1	1	LA	1	1
	PM	1	1		1	1
INTERNAL:	DSB FILE H ST01	2	2	I&E PUBLIC AFFAIRS	2	2
	DGC	1	1		1	1
EXTERNAL:	LPDR	1	1	NRC PDR NTIS	1	1
	NSIC	1	1		1	1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 13 ENCL 13