

CONTROL BLOCK: 1 2 3 4 5 6 7 8 9 10 (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

(1) 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

N J O C P 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 58 59

REPORT SOURCE L 6 0 5 0 0 0 2 1 9 7 0 8 1 9 8 1 8 0 9 1 8 8 1 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

0 2 | During an operational transient of the RBCCW pumps, a RBCCW heat
0 3 | exchanger was subjected to an excessive system flow. Resultant
0 4 | tube vibration caused a tube failure. The safety significance
0 5 | is considered minimal because of the small amount of RBCCW System
0 6 | leakage.

0 8		9		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE	
0 9		G		W B 11		D 12		Z 13		H T E X C H 14				C 15		Z 16	
				EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.					
17 LER-RO REPORT NUMBER		8 1 21		— 23		0 3 9 24		0 3 28		L 30		0 32					
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
B 18		G 19		Z 20		Z 21		0 0 0 0 22		Y 23		N 24		L 25		B 5 7 0 26	

1 0 Inadequate operating procedures resulted in a RBCCW System surge.

1 1 The heat exchangers were isolated one at a time and faulty tubes

1 0 were repaired.

1	4											80						
8	9	FACILITY STATUS		% POWER			OTHER STATUS			(30)	METHOD OF DISCOVERY		DISCOVERY DESCRIPTION			(32)	80	
1	5	H	(28)	0	0	0	(29)	NA			(44)	A	(31)	Operator Observation			(80)	
8	9	ACTIVITY CONTENT RELEASED OF RELEASE		AMOUNT OF ACTIVITY			(35)				(44)	LOCATION OF RELEASE			(36)	80		
1	6	Z	(33)	Z	(34)	NA			(44)	NA			(45)				(80)	
8	9	PERSONNEL EXPOSURES NUMBER		TYPE		DESCRIPTION			(39)								80	
1	7	0	0	0	(37)	Z	(38)	NA			(23)						(80)	
8	9	PERSONNEL INJURIES NUMBER		DESCRIPTION			(41)											80
1	8	0	0	0	(40)	NA			(23)						(80)			
8	9	LOSS OF OR DAMAGE TO FACILITY TYPE		DESCRIPTION			(43)											80
1	9	Z	(42)	NA			(23)											(80)

PUBLICITY
 ISSUED DESCRIPTION (45)
 2 8109290248 810918
 PDR ADOCK 05000219
 S PDR
 Weekly News Release
 K.O.E. Fickeissen, Jr.
 609-693-6776
 NRC USE ONLY
 68 69 80