

systems which will not remove more than one train of each system from service. Maintenance shall not be performed on components which would make the affected system train inoperable for more than 24 consecutive hours. Prior to initiating maintenance on any component of a train in any system, the redundant component of that system shall be demonstrated to be operable within 24 hours prior to the maintenance.

3.3.6 If the conditions of Specifications 3.3.1, 3.3.2, 3.3.3, 3.3.4 and 3.3.5 cannot be met except as noted in 3.3.7 below, reactor shutdown shall be initiated and the reactor shall be in hot shutdown condition within 36 hours, and, if not corrected, in cold shutdown condition within an additional 72 hours.

3.3.7 Exceptions to 3.3.6 shall be as follows:

- (A) If the conditions of Specification 3.3.1(F) cannot be met, reactor operation is permissible only during the succeeding seven days unless such components are sooner made operable, provided that during such seven days the other BWST level instrument channel shall be operable.
- (B) If the conditions of Specification 3.3.3(D) cannot be met, reactor operation is permissible only during the succeeding seven days unless such components are sooner made operable, provided that during such seven days the other CFT instrument channel (pressure or level) shall be operable.
- (C) If the conditions of Specification 3.3.4(A) cannot be met because one group of the required reactor building emergency cooling units is inoperable but both reactor building spray systems are operable, restore the inoperable group of cooling units to operable status within 7 days or be in at least hot shutdown within the next 6 hours and in cold shutdown within the following 30 hours.
- (D) If the conditions of Specification 3.3.4(A) cannot be met because two groups of the required reactor building emergency cooling units are inoperable but both reactor building spray systems are operable, restore at least one group of cooling units to operable status within 72 hours or be in at least hot shutdown within the next 6 hours and in cold shutdown within the following 30 hours. Restore both above required groups of cooling units to operable status within 7 days of initial loss or be in at least hot shutdown within the next 6 hours and in cold shutdown within the following 30 hours.

- (E) If the conditions of Specification 3.3.4(A) cannot be met because one group of the required reactor building emergency cooling units are inoperable and one reactor building spray system is inoperable, restore the inoperable spray system to operable status within 72 hours or be in at least hot shutdown within the next 6 hours and in cold shutdown within the following 30 hours. Restore the inoperable group of reactor building emergency cooling units to operable status within 7 days of initial loss or be in at least hot shutdown within the next 6 hours and in cold shutdown within the following 30 hours.
- (F) If the conditions of Specification 3.3.4(A) cannot be met because any cooling units of the required groups is inoperable because its associated fan is inoperable, verify that the operable cooling unit in that group has a service water flow rate ≥ 1200 gpm through its cooling coils or restore the inoperable cooling unit to operable status within 7 days or be in at least hot shutdown within the next 6 hours and in cold shutdown within the following 30 hours.

Bases

The requirements of Specification 3.3.1 assure that below 350°F, adequate long term core cooling is provided. Two low pressure injection pumps are specified. However, only one is necessary to supply emergency coolant to the reactor in the event of a loss-of-coolant accident.

The post-accident reactor building cooling and long-term pressure reduction may be accomplished by four cooling units, by two spray units or by a combination of one cooling unit and one spray unit. Post-accident iodine removal may be accomplished by one of the two spray system strings. The specified requirements assure that the required post-accident components are available for both reactor building cooling and iodine removal. Specification 3.3.1 assures that the required equipment is operational.

The borated water storage tank is used for three purposes:

- (A) As a supply of borated water for accident conditions.
- (B) As an alternate supply of borated water for reaching cold shutdown. (2)
- (C) As a supply of borated water for flooding the fuel transfer canal during refueling operation. (3)

CONTAINMENT SYSTEMS

CONTAINMENT COOLING SYSTEM

LIMITING CONDITION FOR OPERATION

- 3.6.2.3 Two independent containment cooling groups shall be OPERABLE with at least one operational cooling unit in each group.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

- a. With one group of the above required containment cooling units inoperable and both containment spray systems OPERABLE, restore the inoperable group of cooling units to OPERABLE status within 7 days or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With two groups of the above required containment cooling units inoperable and both containment spray systems OPERABLE, restore at least one group of cooling units to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours. Restore both above required groups of cooling units to OPERABLE status within 7 days of initial loss or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- c. With one group of the above required containment cooling units inoperable and one containment spray system inoperable, restore the inoperable spray system to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours. Restore the inoperable group of containment cooling units to OPERABLE status within 7 days of initial loss or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- d. With any cooling unit of the above required groups inoperable because its associated fan is inoperable, verify that the OPERABLE cooling unit in that group has a service water flow rate ≥ 1250 gpm through its cooling coils or restore the inoperable cooling unit to OPERABLE status within 7 days or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.