

## Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000

Docket Nos: 50-460  
50-513

September 21, 1981  
G01-81-316

Mr. Steven A. Varga  
Acting Assistant Director  
for Lightwater Reactors  
Division of Project Management  
U. S. Nuclear Regulatory  
Commission  
Washington, D. C. 20555



Dear Mr. Varga:

Subject: NUCLEAR PROJECTS 1 AND 4  
CATEGORY I MASONRY WALLS EMPLOYED BY  
PLANTS UNDER CP AND OL REVIEW

Reference: Letter, S. A. Varga to All Construction Permit and  
License Applicants, April 21, 1980.


The reference letter requested all CP and OL applicants to submit information on the use of Category I Masonry Walls.

There are no safety related supports for utilities such as pipes, struts, conduits attached to masonry walls in WNP-1/4 Projects.

There are masonry walls in Category I structures but these masonry walls do not support safety related systems and components. Also, the collapse of the masonry walls will not damage safety related items.

This concludes our response to the subject letter.

Very truly yours,

  
for D. W. Mazur  
WNP-1/4 Program Director

VBM/moe

cc:  
Mr. C. R. Bryant, BPA (399)  
Mr. V. Mani, UE&C-Site (898)

Boo!  
s  
1/0