

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

## REPORT

REPORT SOURCE L 6 0 5 0 - 0 3 2 4 7 0 9 0 4 8 1 8 0 9 1 8 8 1 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During the performance of ADS Reactor Low Water Level No. 1 Channel Calibration and

0 3 | Functional Test, PT 11.1.6PC, it was found that reactor level instrument, 2-B21-LIS-

0 4 | N042B, Model No. 4418, actuated at 154.8" reactor level. This instrument is required

0 5 | to provide an input to the "B" ADS logic at 162.5" reactor vessel level. This event

0 6 | did not affect the health and safety of the public.

0 7 |

Technical Specifications 3.3.3, 6.9.1.9b

C 9		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE	
7 8		I B		E		E		I N S T R U				S		Z	
		9 10		11		12		13 14 15 16 17 18				19		20	
17		EVENT YEAR				SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.			
LER/RO REPORT NUMBER		8 1		—		0 9 5		/		0 3		L		—	
		21 22		23		24 25 26		27		28 29		30		31	
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER	
E		C		Z		Z		0 0 0 0		N		Y		N	
18		19		20		21		22		23		24		25	
33 34		35 36		37 38 39 40		41		42		43		44 45 46 47			

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The instrument was checked and found out of calibration attributable to instrument  
1 1 drift. It was then calibrated according to the PT and was returned to service. A  
1 2 check of the operating history of this instrument did not reveal any previous events  
1 3 involving instrument drift. This instrument is scheduled for replacement with digital  
1 4 analog-type instrumentation during a future unit outage.

FACILITY STATUS										% POWER				OTHER STATUS										METHOD OF DISCOVERY		DISCOVERY DESCRIPTION									
1	5	F	28	0	8	8	29	NA										B	31	Periodic test															
ACTIVITY CONTENT										AMOUNT OF ACTIVITY										LOCATION OF RELEASE															
1	6	Z	33	Z	34	NA										NA																			
PERSONNEL EXPOSURES										DESCRIPTION																									
1	7	0	0	0	37	Z	38	NA																											
PERSONNEL INJURIES										DESCRIPTION																									
1	8	0	0	0	40	NA																													
LOSS OF OR DAMAGE TO FACILITY										DESCRIPTION																									
1	9	Z	42	NA																															

PUBLICITY

		ISSUED	DESCRIPTION	(45)
2	0	3	(44) NA	

NRC USE ONLY

8109290351 810918  
PDR ADCK 05000324  
S PDR

M. J. Pastva, Jr.

PHONE: (919) 457-9521