

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 AR AN 01 00 -0 00 00 -00 04 11 11 11 04 05

LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 27 57 CAT 58

CON'T

01 L 0 5 0 0 0 3 1 3 0 7 2 7 8 1 0 8 2 6 8 1 0

REPORT SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During Hot Shutdown conditions, while performing a start test of the

03 Steam Driven Emergency Feedwater (EFW) pump, P7A, Steam Supply from Steam

04 Generator "B" valve, CV-2617, failed to open on demand. The redun-

05 dant steam supply path remained operable and the electric driven EFW pump

06 was available. This occurrence is similar to LER's 50-313/80-012, 80-005,

07 & 78-002. Reportable per T.S.6.12.3.2.b.

08

09 HH E A V A L V O P A Z

SYSTEM CODE 9 10 CAUSE CODE 11 CAUSE SUBCODE 12 COMPONENT CODE 13 COMP SURCODE 14 VALVE SURCODE 15

17 8 1 0 0 9 0 3 L 0

LER/RO REPORT NUMBER 21 22 EVENT YEAR 23 SEQUENTIAL REPORT NO. 24 OCCURRENCE CODE 25 REPORT TYPE 26 REVISION NO. 32

18 Z Z Z 0 0 0 N Y A L 2 0 0

ACTION TAKEN 33 FUTURE ACTION 34 EFFECT ON PLANT 35 SHUTDOWN METHOD 36 HOURS 37 ATTACHMENT SUBMITTED 40 NPRD-4 FORM SUB 42 PRIME COMP. SUPPLIER 43 COMPONENT MANUFACTURER 44

CAUSE DESCRIPTION AND CORRECTIVE ACTION: (27)

10 Investigation revealed that the valve operator torque switch assembly had

11 excessive play indicating a normal wear out condition. The torque switch

12 was replaced and the valve returned to service, meeting the requirements

13 of T.S.3.4.1.6. and T.S.3.4.3.

14

15 D 0 0 0 N/A C Start test of EFW turbine.

FACILITY STATUS 28 % POWER 29 OTHER STATUS 30 METHOD OF DISCOVERY 31 DISCOVERY DESCRIPTION 32

16 Z Z NA NA

ACTIVITY RELEASED 33 CONTENT OF RELEASE 34 AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36

17 0 0 0 Z NA

PERSONNEL EXPOSURES NUMBER 37 TYPE 38 DESCRIPTION 39

18 0 0 0 NA

PERSONNEL INJURIES NUMBER 40 DESCRIPTION 41

19 Z NA

LOSS OF OR DAMAGE TO FACILITY TYPE 42 DESCRIPTION 43

20 N NA

PUBLICITY ISSUED 44 DESCRIPTION 45

21 N NA

NRC USE ONLY

NAME OF PREPARER Chris N. ShivelyPHONE: 501/968-2519