

Mailing Address  
Alabama Power Company  
600 North 18th Street  
Post Office Box 2641  
Birmingham, Alabama 35291  
Telephone 205 783-6081

F. L. Clayton, Jr.  
Senior Vice President  
Flintridge Building



September 23, 1981

Docket No. 50-348

Director, Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Attention: Mr. S. A. Varga

Completion of Generic Item B-24 and  
TMI Action Item II.E.4.2.5



Gentlemen:

Your letter of August 5, 1981 requested Alabama Power Company to propose Technical Specifications consistent with the resolution of Generic Item B-24 and TMI Action Item II.E.4.2.5. In particular, Technical Specifications were requested for items 2 (Valve Operability) and 4 (Containment Leakage Due to Seal Deterioration). Technical Specifications for these items on the currently installed 48 inch purge valves and 18 inch purge valves were proposed to the NRC in the Alabama Power Company letter dated May 28, 1981 as part of the Unit 1 Technical Specification upgrade. In addition, the May 28, 1981 submittal also included a revised minimum containment isolation setpoint which is consistent with the resolution of item 5 (Containment Pressure Setpoint for Containment Isolation).

As part of the Unit 2 full power NPF-8 license condition 2.C.17 Alabama Power Company will be submitting by October 1, 1981, the design of the modified containment vent and purge system. Prior to installation of the 8 inch purge valves, Alabama Power Company will propose revised Technical Specifications for the containment purge system.

If you have any questions, please advise.

Yours very truly,

*F. L. Clayton, Jr.*  
F. L. Clayton, Jr.

FLCJr/JAR:wm

cc: See Page 2

*A046  
5/10*

8109290488 810923  
PDR ADDCK 05000348  
P PDR

Director, Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission

September 23, 1981  
Page 2

cc: Mr. R. A. Thomas  
Mr. G. F. Trowbridge  
Mr. J. P. O'Reilly  
Mr. E. A. Reeves  
Mr. W. H. Bradford