

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

REPORT
SOURCE

0	1
7	8

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | It was determined on August 14, 1981, that on August 9, 1981, the total dissolved
0 3 | solids (TDS) in the plant nonradioactive liquid waste effluent exceeded the 2,200 parts
0 4 | per million limit of LCO NR 1.1. This is reportable per Fort St. Vrain Technical
0 5 | Specification AC 7.5.2(b)2. There was no effect on public health or safety. No ac-
0 6 | companying occurrences. Similar report: RO 81-022.
0 7 |
0 8 |

SYSTEM CODE H F 11		CAUSE CODE A 12		CAUSE SUBCODE B 13		COMPONENT CODE Z Z Z Z Z Z 14				COMP. SUBCODE Z 15		VALVE SUBCODE Z 16	
LER/RO REPORT NUMBER 17		EVENT YEAR 8 1 22		SEQUENTIAL REPORT NO. 0 5 0 24		OCCURRENCE CODE 0 3 28		REPORT TYPE L 30		REVISION NO. 0 32			
ACTION TAKEN X 18		FUTURE ACTION Z 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22		ATTACHMENT SUBMITTED Y 23		NPRD-4 FORM SUB. N 24	
PRIME COMP. SUPPLIER N 25		COMPONENT MANUFACTURER Z 9 9 9 26											

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 6 High total dissolved solids resulted from an increase in plant power level and the

1 1 improper circulating water blowdown arrangement. After the problem was noted, the

1 2 blowdown was adjusted to the proper level, and the liquid effluent total dissolved

1 3 solids returned to acceptable levels.

1 4

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

FACILITY STATUS (28) 0 6 9 (29) N/A (30) METHOD OF DISCOVERY (31) Personnel Observation (32) DISCOVERY DESCRIPTION

ACTIVITY CONTENT (33) Z (34) Z (35) N/A (36) LOCATION OF RELEASE

RELEASED OF RELEASE AMOUNT OF ACTIVITY

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37) Z (38) N/A	(39)			

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	0	N/A

		LOSS OF OR DAMAGE TO FACILITY		(43)
		TYPE	DESCRIPTION	
1	9	Z(42)	N/A	

8 9 10
 PUBLICITY
 ISSUED DESCRIPTION (45)
 2 0 N (4) N/A
 7 8 9 10
 8109290503 810911
 PDR ADCK 05000267
 S PDR
 68 69 70
 MAR USE ONLY

NAME OF PREPARER

mit m. Binde

PHONE: (303) 785-2224