

UNITED STATES NUCLEAR REGULATORY COMMISSION

In the Matter of )

NIAGARA MOHAWK POWER CORPORATION )

Docket No. 50-410

Nine Mile Point Nuclear Station Unit No. 2 )

APPLICATION FOR AMENDMENT

TO

OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, Niagara Mohawk Power Corporation, holder of Facility Operating License No. NPF-69, hereby requests that Sections 1.0 and 3/4.3.6 of the Technical Specifications set forth in Appendix A to that License be amended. The proposed changes have been reviewed in accordance with Section 6.5 of the Technical Specifications.

The proposed changes to the Technical Specifications are set forth in Attachment A to this application. Definition 1.9, "Critical Power Ratio," is being proposed for revision to replace the designation for the General Electric critical power correlation, "GEXL," with a more generic term. Section 3/4.3.6, including Table 3.6-2, "Control Rod Block Instrumentation Setpoints," is being proposed for amendment in order to revise the setpoints for the Recirculation Flow Upscale Rod Block. The setpoints for the Recirculation Flow Upscale Rod Block are being proposed for revision to facilitate operation at 105% rated core flow.

The proposed changes would not authorize any change in the types of effluents or in the authorized power level of the facility. Supporting information and analyses which demonstrate that the proposed change involves no significant hazards consideration pursuant to 10 CFR § 50.92 are included as Attachment B.

WHEREFORE, Applicant respectfully requests that Appendix A to Facility Operating License No. NPF-69 be amended in the form attached hereto as Attachment A.

NIAGARA MOHAWK POWER CORPORATION

By: \_\_\_\_\_

*B. R. Sylwia*

B. R. Sylwia

Exec. Vice President - Nuclear

Subscribed and Sworn to before me  
on this 11 day of Nov 1993

*Beverly W. Ripka*  
NOTARY PUBLIC

BEVERLY W. RIPKA  
Jurat: I am a Notary Public in New York  
County of Oswego No. 4044879  
My Commission exp. date 11/13/94  
2/27/94

9303090034 930227  
PDR ADDOCK 05000410  
P PDR

003414LL