

From: Habib, Donald
Sent: Wednesday, January 15, 2020 3:28 PM
To: Arafeh, Yasmeen N.
Cc: Rankin, Jennivine; Patel, Pravin; Lehman, Bryce; Vogtle PEmails
Subject: Discussion of Vogtle LAR 19-019 at January 16, 2020, Public Meeting

Yasmeen –

For LAR 19-019, the staff notes that on Enclosure 2, pages 25 of 33 and 27 of 33, the final column includes required/provided ratio values of 1.0 and 0.99, and the column is footnoted that “Two percent of the value may be added to the design limit as an allowance for minor variances in analysis results.”

In a previous public meeting, the staff pointed out that adding two percent would increase the ratios above 1.0. The staff would like to discuss this matter at a future public meeting (e.g., 1/16).

Donald Habib
Project Manager, Vogtle Project Office
U.S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
301-415-1035

Hearing Identifier: Vogtle_COL_Docs_Public
Email Number: 520

Mail Envelope Properties (DM6PR09MB3019A2264CD06042BDEF9EFC97370)

Subject: Discussion of Vogtle LAR 19-019 at January 16, 2020, Public Meeting
Sent Date: 1/15/2020 3:28:08 PM
Received Date: 1/15/2020 3:28:10 PM
From: Habib, Donald

Created By: Donald.Habib@nrc.gov

Recipients:

"Rankin, Jennivine" <Jennivine.Rankin@nrc.gov>
Tracking Status: None
"Patel, Pravin" <Pravin.Patel@nrc.gov>
Tracking Status: None
"Lehman, Bryce" <Bryce.Lehman@nrc.gov>
Tracking Status: None
"Vogtle PEmails" <Vogtle.PEmails@nrc.gov>
Tracking Status: None
"Arafeh, Yasmeen N." <YNARAFEH@southernco.com>
Tracking Status: None

Post Office: DM6PR09MB3019.namprd09.prod.outlook.com

Files	Size	Date & Time
MESSAGE	695	1/15/2020 3:28:10 PM

Options

Priority: Normal
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date: