



GPU Nuclear Corporation
Post Office Box 480
Route 441 South
Middletown, Pennsylvania 17057
717 944-7621
TELEX 84-2386
Writer's Direct Dial Number:

December 17, 1982
5211-82-263


Office of Nuclear Reactor Regulation
Attn: D. G. Eisenhut, Director
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Sir:

Three Mile Island Nuclear Station, Unit 1 (TMI-1)
Operating License No. DPR-50
Docket No. 50-289
NUREG 0737 Technical Specifications
Response to Generic Letter No. 82-16

The enclosure to this letter is GPUN's response to Generic Letter 82-16.

Sincerely,


H. D. Hukill
Director, TMI-1

HDH:CWS:vjf

Enclosure

cc: R. C. Haynes
J. Van Vliet

8212270134 821217
PDR ADOCK 05000289
P PDR

A046

Response to Generic Letter 82-16 NRC Staff Guidance Concerning
Technical Specifications (TS) Required by NUREG 0737

1. STA Training (I.A.1.1.3)

Resolved by TS 6.2.2 and 6.3.3 issued with Amendment 77 to the TMI-1 TS.

2. Limit Overtime (I.A.1.3)

See GPUN Letter 5211-82-295 dated December 16, 1982.

3. Short Term EFW Evaluation (II.E.1.1)

Resolved by TS 3.4 and 4.9 issued with Amendment 78 to the TMI-1 TS.

4. Safety Grade EFW Initiation and Flow Indication (II.E.1.2)

TMI-1 is upgrading the EFW System to safety grade during Cycle 6 refueling. Additional TS changes, if necessary, will be filed at that time for EFW initiation and control.

EFW flow indication is covered by TS 3.5.5 and 4.1 (Table 4.1-1 item 50) issued with Amendment 78 to the TMI-1 TS.

5. Dedicated Hydrogen Penetrations (II.E.4.1)

TS Change Request (TSCR) 109 filed January 26, 1982 addresses the Hydrogen Recombiner. TSCR - 113 filed April 21, 1982 addresses the Appendix J requirements for the Hydrogen Recombiner valves.

6. Containment Pressure Setpoint (II.E.4.2.5)

Existing TS cover this item as documented in the NRC evaluation for this item forwarded to GPUN by NRC letter dated April 21, 1981.

7. Containment Purge Valve (II.E.4.2.6)

Proposed TS addressing the containment purge valves were forwarded by TSCR 116 filed August 13, 1982.

8. Radiation Signal on Purge Valves (II.E.4.2.7)

Resolved by TS 3.5 (table 3.5-1 item C.3.f) and 4.1 (table 4.1-1 item 19.e) issued with Amendment 78 to the TMI-1 TS.

9. Upgrade B&W EFW System (II.K.2.8)

See response to item 4 above (II.E.1.2)

10. (Enclosure 1 to Generic Letter 82-16 does not list an item 10)

11. B&W Thermal-Mechanical Report (II.K.2.13)

GPUN responded to this item by letter dated June 1, 1982 (5211-82-132) and July 7, 1982 (5211-82-163). No Technical Specifications were deemed necessary and none were proposed.

12. Reporting of SV and RV Failures and Challenges (II.K.3.3)

Resolved by TS 6.9.1.B.4 and 6.9.2.A.10 issued with Amendment 77 to the TMI-1 TS.

13. Anticipatory Trip on Turbine Trip (II.K.3.12)

Resolved by TS 3.5 (Table 3.5-1 item B.1 and B.2) and TS 4.1 (Table 4.1-1 items 45 and 46).