

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 ALJMF1 200-00000-00 3411111 4 5

CON'T 01 REPORT SOURCE L 605000348 7040283 8042783 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 At 1813 on 4/2/83, Overtemperature-Delta Temperature Loop 2 Channel II was

03 declared inoperable when bistables 422C₁ and 422C₂ tripped. Tech. Spec. 3.3.1,

04 in part, requires this instrumentation channel to be operable. Tech. Spec.

05 3.3.1 action statement requirements were met. Health/safety of the public

06 was not affected.

07

08

09 IA 11 E 12 G 13 INSTRU 14 P 15 Z 16

17 LER RO REPORT NUMBER 83 21 — 22 012 23 — 24 03 25 L 26 — 27 0

ACTION TAKEN C 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0000 22 ATTACHMENT SUBMITTED N 23 NPRO-4 FORMSUS Y 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER W120 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 This event was due to a power supply failure of a comparator card. Following

11 replacement of the card and calibration of the instrumentation loop, Overtemper-

12 ature-Delta Temperature Loop 2 Channel II was declared operable at 0340 on

13 4/3/83.

14

15 E 28 075 29 NA 30 A 31 Operational Event 32

16 Z 33 Z 34 NA 35 NA 36

17 000 37 Z 38 NA 39

18 000 40 NA 41

19 Z 42 NA 43

20 N 44 NA 45

8305050158 830427
PDR ADOCK 05000348
3 PDR

NAME OF PREPARER W. G. Hairston, III

PHONE (205) 899-5156