

## WISCONSIN PUBLIC SERVICE CORPORATION



P.O. Box 1200, Green Bay, Wisconsin 54305

June 7, 1983

Mr. J. G. Keppler, Regional Administrator  
Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Dear Mr. Keppler:

Docket 50-305  
Operating License DPR-43  
Kewaunee Nuclear Power Plant  
IE Bulletin 83-03: Check Valve Failures in Raw Water Cooling  
Systems of Diesel Generators

In response to the "Required Actions for Holders of Operating Licenses" in the reference IE Bulletin:

A review of drawings and a physical walkdown of cooling water piping for the Diesel Generators has verified that there are no check valves in this flow path. Therefore, the requested actions are not applicable to Kewaunee Nuclear Power Plant.

Approximately two (2) hours of staff time was expended to prepare this response.

Very truly yours,

A handwritten signature in cursive script, appearing to read "C. W. Giesler".

C. W. Giesler  
Vice President - Nuclear Power

js

cc - Mr. S. A. Varga, US NRC  
Mr. Robert Nelson, US NRC

8306170056 830607  
PDR ADOCK 05000305  
Q PDR

JEI 40  
JUN 9 1983