

## 3150-0011

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

PHONE: (717) 542-2181 X3759



# Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

May 26, 1983

Mr. J.M. Allan  
Acting Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION  
LICENSEE EVENT REPORT 83-071/03L-0  
ER 100450 FILE 841-23  
PLA-1688

Docket No. 50-387  
License No. NPF-14

Dear Mr. Allan:

Attached please find a copy of Licensee Event Report No. 83-071/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.a, in that the overvoltage setting of one of the reactor protection system alternate electrical protection assemblies was found to be greater than the Technical Specification limit.

H.W. Keiser  
Superintendent of Plant-Susquehanna

LAK/pjg

cc: Director of Nuclear Reactor Regulation  
Attention: Mr. A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

G.G. Rhoads  
Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 52  
Shickshinny, PA 18655

IE 22  
11