

No. 2-83-10/3L

THIS L.E.R. DEALS WITH THE FAILURE OF A SELECTOR VALVE
IN THE D/W RADIOACTIVE GAS SAMPLING SYSTEM.

LICENSEE EVENT REPORT

CONTROL BLOCK: (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 P A P B S 2 2 0 0 0 0 0 0 0 0 0 0 3 4 1 1 1 1 4 5

LICENSEE CODE 14 15 LICENSE NUMBER 26 26 LICENSE TYPE 30 30 CAT 58 58

CON'T

0 1 REPORT SOURCE L 0 0 5 0 0 0 2 7 7 7 0 4 2 7 8 3 8 0 5 2 6 8 3 0

DU DOCKET NUMBER 60 60 EVENT DATE 74 75 REPORT DATE 80 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During full power operation, an operator noticed a no flow indication

0 3 on a sample line flow meter and found 3-way selector valve, SV-2524,

0 4 to be stuck. The valve was tapped and flow returned. The D/W

0 5 sump flowmeters remained operable. Applicable Tech. Spec. is 3.6.C.2.

0 6

0 7

0 8

0 9

SYSTEM CODE 0 10 CAUSE CODE 11 CAUSE SUBCODE 12 COMPONENT CODE 13 VALVE X 14 COMP. SUBCODE 15 VALVE SUBCODE 16

17 LER/RO REPORT NUMBER 8 3 0 1 0 0 3 L 0

SEQUENTIAL REPORT NO. 24 25 OCCURRENCE CODE 26 27 REPORT TYPE 30 REVISION NO. 32

ACTION TAKEN 33 FUTURE ACTION 34 EFFECT ON PLANT 35 SHUTDOWN METHOD 36 HOURS 37 ATTACHMENT SUBMITTED 40 NPD-4 FORM SUB 42 PRIME COMP. SUPPLIER 43 COMPONENT MANUFACTURER 44

D 16 Z 19 Z 20 Z 21 0 0 0 0 N 23 Y 24 A 25 A 4 9 9

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Probable cause of failure was build up of dirt inside solenoid valve

1 1 (ASCO, Model S36-734). Valve is currently in operation and will be

1 2 disassembled and inspected within a month.

1 3

1 4

FACILITY STATUS 7 8 9 10 % POWER 11 12 OTHER STATUS 13 14 METHOD OF DISCOVERY 15 16 DISCOVERY DESCRIPTION 17 18

1 5 E 20 1 0 0 29 N/A A 31 OPERATIONAL EVENT 32

ACTIVITY 33 CONTENT 34 RELEASE OF RELEASE 35 AMOUNT OF ACTIVITY 36 LOCATION OF RELEASE 37

1 6 Z 33 Z 34 N/A N/A 30

PERSONNEL EXPOSURES 38 39

1 7 0 0 0 37 Z 38 N/A

PERSONNEL INJURIES 40 41

1 8 0 0 0 40 N/A

LOSS OF OR DAMAGE TO FACILITY 42 43

1 9 Z 42 N/A

PUBLICITY 44 45

2 0 N 44 N/A

NAME OF PREPARER M. J. Cooney

PHONE (215) 811-1020

8304170278 830526 PDR ADOCK 05000277 PDR