

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

L	6	0	5	0	0	0	2	4	7	7	0	4	2	2	8	3	8	0	5	2	2	8	3	9
60	61	DOCKET NUMBER										68	EVENT DATE					74	REPORT DATE					80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

A plant shutdown commenced when the binding of valve No. 1870 could not be

corrected within the time period allowed in Technical Specification 3.6.A.5a.

Valve No. 1870 is one of two in series non-automatic containment isolation valves

on the RHR test and minimum flow recirculation line. The health and safety of the

public were unaffected. There were no similar pervious events.

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

The binding of valve No. 1870 was alleviated by lubricating the valve stem and the

universal joints between the actuator and the valve. The valve was stroked

satisfactorily and returned to service. Mfr. Data: Limitorque Model SMB-000

attached to a 2" Conval Globe Valve Fig. 2-12G-316.

8306170410 830522
PDR ADCK 05000247
S PDR

NRC USE ONLY

John D. O'Toole
Vice President

Consolidated Edison Company of New York, Inc.
4 Irving Place, New York, NY 10003
Telephone (212) 460-2533

May 22, 1983

Re: Indian Point Unit No. 2
Docket No. 50-247
LER-83-018/03L-0


Mr. James M. Allan,
Acting Regional Administrator-Region I
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pa. 19406

Dear Mr. Allan:

The attached Licensee Event Report LER-83-018/03L-0 is hereby submitted in accordance with the requirements of Technical Specification 6.9.1.7. This event is of the type described in Technical Specification 6.9.1.7.2.b.

Three copies of this letter and attachment are enclosed as required.

Very truly yours,



attach.

cc:

Mr. Richard DeYoung, Director (30 copies)
Office of Inspection and Enforcement
c/o Distribution Services Branch, DDC, ADM
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. William G. McDonald, Director (3 copies)
Office of Management Information and Program Control
c/o Distribution Services Branch, DDC, ADM
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. Thomas Foley, Senior Resident Inspector
U. S. Nuclear Regulatory Commission
P. O. Box 38
Buchanan, New York 10511

IE 22
11