

CONTROL BLOCK:

--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	D	C	C	N	2	2	0	0	-	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE				30	57	CAT 58	

CON'T

REPORT SOURCE 0 1 7 8

DOCKET NUMBER 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

EVENT DATE 0 5 0 4 8 3

REPORT DATE 0 6 0 2 8 3

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | At 1200 during normal operation, the containment sump alarm was declared

0 3 | inoperable (T.S. 3.4.6.1). Investigation revealed the alarm card was de-

0 4 | fective. The alarm card was replaced and the containment sump alarm was

0 5 | returned to service at 2210. The containment gaseous and particulate

0 6 | radioactivity monitoring systems remained operable throughout the event.

0 7 | Similar events: none.

0 8 |

[illegible]

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The cause for this event was the failure of the containment's sump alarm

1 1 | annunciator card to alarm. The alarm card was replaced with a stock

1 2 | spare and sent to the shop for repair. A check of the annunciator alarm

1 3 | will be changed from weekly to daily under the preventive maintenance

1 4 | program. No further actions are deemed necessary.

8 9

FACILITY STATUS		% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
1	5	E (28)	1 0 0 (29) N/A	A (31)	Operator Observation

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

1 6 2 33 2 34 N/A N/A

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	Z	(38)	N/A	(39)

PERSONNEL INJURIES	
NUMBER	DESCRIPTION
000	N/A

8306170420 830602
PDR ADOCK 05000318
S PDR

		PUBLICITY	(45)	NRC USE ONLY
ISSUED	DESCRIPTION			
20	N/A			

NRC USE ONLY

NAME OF PREPARER M. A. Junge/J. W. Raynor

PHONE: 301-269-4969/4713

BALTIMORE GAS AND ELECTRIC COMPANY

P.O. BOX 1475
BALTIMORE, MARYLAND 21203

NUCLEAR POWER DEPARTMENT
CALVERT CLIFFS NUCLEAR POWER PLANT
LUSBY, MARYLAND 20657

June 2, 1983

Mr. James M. Allan
Acting Regional Administrator
U. S. Nuclear Regulatory Commission
Region 1
631 Park Avenue
King of Prussia, PA 19406

Docket No. 50-318
License No. DPR 69

Dear Mr. Allan:

In accordance with Technical Specification 6.9 please find the attached thirty day report for LER 83-21/3L.

Should you have any questions regarding this report, we would be pleased to discuss them with you.

Very truly yours,

LBR Russell
L. B. Russell
Plant Superintendent

LBR:JWR:bsb

cc: Director, Office of Management Information
and Program Control
Messrs: A. E. Lundvall, Jr.
J. A. Tiernan

IE22
11