

LICENSEE EVENT REPORT

LER 83-15/1P

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 V T V Y S 1 0 0 - 0 0 0 0 0 - 0 0 4 1 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T

0 1 REPORT SOURCE L 0 5 0 0 0 2 7 1 0 6 0 8 8 3 0 6 0 9 8 3 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 Yankee Atomic Electric Co. informed Vermont Yankee that additional piping
0 3 supports are required to support copper piping in the service water system
0 4 and for torus attached piping.
0 5
0 6
0 7
0 8

0 9 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
X X 11 X 12 X 13 Z Z Z Z Z Z 14 Z 15 Z 16
7 8 9 10 11 12 13 18 19 20
17 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
8 3 0 1 5 0 1 P 0
21 22 23 24 26 27 28 29 30 31 32
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NRPD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
X 18 X 19 Z 20 Z 21 0 0 0 0 N 23 N 24 X 25 Z 9 9 9 9 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Cause description and corrective actions for this occurrence will be provided
1 1 in the 14-day report.
1 2
1 3
1 4


1 5 FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION
H 28 0 0 0 29 NA D 31 Review of Piping Calculations
7 8 9 10 12 13 44 45 46 80
1 6 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE
Z 33 Z 34 NA
7 8 9 10 11 44 45 80
1 7 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION
0 0 0 37 Z 38 NA
7 8 9 11 12 13 80
1 8 PERSONNEL INJURIES NUMBER DESCRIPTION
0 0 0 40 NA
7 8 9 11 12 80
1 9 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION
Z 42 NA
7 8 9 10 80
2 0 ISSUED DESCRIPTION PUBLICITY
Y 44 Status Phone
7 8 9 10 80

8307010022 830609
PDR ADOCK 05000271
S PDR

USE ONLY

NAME OF PREPARER James P. Pelletier

PHONE: (802) 257-7711



VERMONT YANKEE NUCLEAR POWER CORPORATION

P. O. BOX 157
GOVERNOR HUNT ROAD
VERNON, VERMONT 05354

June 9, 1983

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

ATTENTION: Dr. Thomas E. Murley, Regional Administrator

REFERENCE: Operating License DPR-28
Docket No. 50-271
Reportable Occurrence No. LER 83-15/1P

Dear Sir:

As defined by Technical Specifications for the Vermont Yankee Nuclear Power Station, Section 6.7.B.1, we are reporting the attached Reportable Occurrence as LER 83-15/1P.

Very truly yours,

James P. Pelletier
Plant Manager

RDP/cjm

IE29
11