

Control Room Indications

- **Low RCS pressure**
- **High PORV discharge
temperature**
- **High drain tank pressure**
- **High drain tank
temperature**
- **Reactor trip**
- **High pressure
injection initiated**