



# THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 5000 - CLEVELAND, OHIO 44101 - TELEPHONE (216) 622-9800 - ILLUMINATING BLDG. - 55 PUBLIC SQUARE

*Serving The Best Location in the Nation*

MURRAY R. EDELMAN

VICE PRESIDENT  
NUCLEAR

July 1, 1983

Mr. James G. Keppler  
Regional Administrator, Region III  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

RE: Perry Nuclear Power Plant  
Docket Nos. 50-440; 50-441  
Piping Supports Supplied by  
Transamerica Delaval, Inc.  
[RDC 67(83)]

Dear Mr. Keppler:

This letter serves as the final report pursuant to 10CFR50.55(e) concerning ASME Code Section III, Class 3, piping supports supplied to the Perry Nuclear Power Plant by Transamerica Delaval, Inc. Mr. P. R. Pelke of your office was first notified on February 23, 1983, by Mr. E. Riley of The Cleveland Electric Illuminating Company (CEI) that this problem was being evaluated. Our previous reports on this subject were submitted March 25, 1983, and April 29, 1983.

This report contains a description of the deficiency, an analysis of safety implications and the corrective action taken.

## Description of Deficiency

Specification 562-4549-00, Section 2:05 Item 3a and Section 2:16 Item 1, require that most piping components are to be built to the ASME Code Section III, Class 3. Transamerica Delaval, contracted under specification 562-4549-00, supplied skid mounted piping supports without material certification and identification as outlined in ASME NF-2130 and NF-2150.

## Analysis of Safety Implications

Engineering analysis has determined that although the supports supplied by DeLaval did not meet the material traceability requirements specified in ASME NF-2130 and NF-2150, there is little probability a safety hazard exists because the supports were seismically qualified.

However, in order to satisfy the subject ASME requirements, corrective action as detailed below has been taken.

JUL 8 1983

8307110316 830701  
PDR ADOCK 05000440  
S PDR

IE27 1/0

July 1, 1983

Corrective Action

DeLaval has completed reanalysis of the skid piping supports and has supplied revised drawings which detail the ASME Section III Subsection NF Support Boundaries and the components which must be modified or replaced to meet Subsection NF criteria. The drawings have been issued to our installing contractor (General Electric) and Code materials are being procured by DeLaval, General Electric, and CEI. These materials will be supplied to General Electric, who will upgrade the supports on s' e.

We anticipate completion of these actions by December 1983.

Please contact us if you have any questions or comments.

Sincerely,

*Cyril M. Shuster for*

Murray R. Edelman  
Vice President  
Nuclear Group

MRE:pab

cc: Mr. M. L. Gildner  
NRC Site Office

Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission  
c/o Document Management Branch  
Washington, D.C. 20555

Records Center, SEE-IN  
Institute of Nuclear Power Operations  
1190 Circle 75 Parkway, Suite 1500  
Atlanta, Georgia 30339