

CP&L

USNRC REGION II
ATLANTA, GEORGIA

Carolina Power & Light Company

P. O. Box 101, New Hill, North Carolina 27562
July 1, 1983

83 JUL 8 All: 29

FILE: SH N-2/18
Item 135

MQAH 83-163

Mr. James P. O'Reilly
United States Nuclear Regulatory Commission
Region II
101 Marietta Street, Northwest
Atlanta, Georgia 30303

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400
PSI WAVEFORMS FOR THE NES PULSERS

Dear Mr. O'Reilly:

This is to confirm the July 1, 1983 telephone conversation between Mr. K. V. Hate' and Mr. A. Hardin. Mr. Hardin was informed that the June 3, 1983 potentially reportable item, pertaining to Nuclear Energy Services (NES) reactor vessel PSI waveforms for the pulsers that appeared to be generated at one time in lieu of prior to release from the factory, prior to use and subsequent to use as required by NES procedure, has been evaluated and considered not to be reportable per the provisions of 10CFR50.55(e).

Thank you for your consideration in the matter.

Yours very truly,

FES/mt

cc: Mr. G. Maxwell
Mr. R. L. Prevatte
Mr. V. Stello

N J Chiangi by KUH
N. J. Chiangi - Manager
Quality Assurance/Quality Control
Harris Plant

OFFICIAL COPY

IL-27
1/0