

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT

CON'T REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES

While in Mode 3 during initial startup, an operator transiting the personnel air lock noticed the inner equalizing valve did not shut. The equalizing valve was shut manually and maintained closed while repairs were made. This was the second event of this type. The health and safety of the public were not adversely affected.

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE

LER/OO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO OCCURRENCE CODE REPORT TYPE REVISION NO

ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRO-4 FORM SUB PRIME COMP SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS

Upon inspection, the operating linkage for the equalizing valve was found to be broken. Further investigation showed that the valve movement was severely restricted. The valve was replaced, the linkage repaired and the air lock declared operable.

FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

ACTIVITY CONTENT RELEASED OF RELEASE ACTIVITY LOCATION OF RELEASE

PERSONNEL EXPOSURE NUMBER TYPE DESCRIPTION


PERSONNEL INJURIES NUMBER DESCRIPTION

LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

PUBLICITY ISSUED DESCRIPTION

NRC USE ONLY

NAME OF PREPARER G. E. Walling PHONE (305)465-3550x3364



June 30, 1983  
PNS-LI-83-461-1

Mr. James P. O'Reilly  
Regional Administrator, Region II  
U. S. Nuclear Regulatory Commission  
101 Marietta Street N.W., Suite 2900  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

REPORTABLE OCCURRENCE 389-83-18

ST. LUCIE UNIT 2

DATE OF OCCURRENCE: MAY 31, 1983

PERSONNEL AIR LOCK

The attached Licensee Event Report is being submitted in accordance with Technical Specification 6.9 to provide 30-day notification of the subject occurrence.

Very truly yours,

*K. Williams*  
J. W. Williams, Jr.  
Vice President  
Nuclear Energy

JWW/PLP/js

Attachment

cc: Director, Office of Inspection and Enforcement (30)  
Harold F. Reis, Esquire  
File 933.1 SL

OFFICIAL COPY

1022

1/1

PEOPLE...SERVING PEOPLE