



DESIGNATED ORIGINAL

Certified By

ma

Public Service Electric and Gas Company P.O. Box E Hancocks Bridge, New Jersey 08038

Salem Generating Station

May 31, 1983

Mr. J. Allan
Acting Regional Administrator
USNRC
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. Allan

REPORTABLE OCCURRENCE 83-022/01P
SALEM NO. 2 UNIT LER

This letter is to confirm our verbal report to the NRC Resident Inspector on Tuesday, May 31, 1983, advising of a reportable occurrence in accordance with Technical Specifications, Section 6.9.1.8.b.

At 0043 hours, May 30, 1983, during routine shutdown operation, a loss of power to No. 2C Vital Instrument Bus occurred, rendering the associated A.C. electrical bus train inoperable. No. 2A Diesel Generator and its associated train were inoperable at the time, requiring entry into Action Statement 3.8.2.2. Due to problems associated with testing the containment air locks, containment integrity was not established within 8 hours as required by the action statement.

An investigation of the occurrence is in progress, and a detailed report will be submitted within the 14 day time period as required by the Technical Specifications.

Sincerely yours,

J. M. Zupko, Jr.
General Manager -
Salem Operations

RF:k1a

8307120238 830531
PDR ADOCK 05000311
S PDR

1/0 IE29