

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 PASES1 200-000000-00 341111 4 5
7 8 9 LICENSE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 38

CONT

01 REPORT SOURCE L 605000387 7052583 8062483 9
7 8 9 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 During surveillance testing, a Containment Isolation Valve for a Containment Atmos-

03 phere Control Sample Line failed to close. The valve was isolated and deactivated

04 electrically. There were no consequential effects to public health and safety.

05

06

07

08

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
S D 11 E 12 A 13 V A L V E X 14 F 15 D 16
7 8 9 10 11 12 13 14 15 16 17 18 19 20

17 LRR/NO REPORT NUMBER 83 21 22 085 23 24 25 03 26 27 28 29 L 30 31 0 32
18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS 22 ATTACHMENT SUBMITTED NPRO-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER 26
X 18 Z 19 Z 20 Z 21 0000 N 23 N 24 A 25 T 0 2 0
33 34 35 36 37 38 39 40 41 42 43 44 45

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 Maintenance personnel verified proper limit switch positioning and used a dead-man

11 switch to allow isolated electrical operation of the valve, then reconnected the

12 circuitry. The valve was then operated several times from the Control Room and

13 operated properly.

14

15 FACILITY STATUS % POWER OTHER STATUS 30 METHOD OF DISCOVERY DISCOVERY DESCRIPTION 32
B 28 008 29 NA B 31 Operator Observation
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

16 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36
Z 33 Z 34 NA NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

17 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39
000 37 Z 38 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

18 PERSONNEL INJURIES NUMBER DESCRIPTION 41
000 40 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

19 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43
Z 42 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

20 PUBLICITY ISSUED DESCRIPTION 45
N 44
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

8307120256 830624
PDR ADOCK 05000387
S PDR

NRC USE ONLY

NAME OF PREPARER A.P. Piemontese

PHONE (717) 542-2181 X3246



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

June 24, 1983

Mr. J.M. Allan
Acting Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 83-085/03L-0
ER 100450 FILE 841-23
PLA-1728

Docket No. 50-387
License No. NPF-14

Dear Mr. Allan:

Attached please find a copy of Licensee Event Report No. 83-085/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.(b), in that during surveillance testing, a Containment Isolation Valve on a sample line in the Containment Atmosphere Control System did not close. Proper operation has been verified and the valve returned to service.

H.W. Keiser
Superintendent of Plant-Susquehanna

APP/pjg

cc: G.G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

IE22
11