

Georgia Power Company  
Post Office Box 4545  
Atlanta, Georgia 30302  
Telephone 404 526-6526

Southern Company Services, Inc.  
Post Office Box 2625  
Birmingham, Alabama 35202  
Telephone 205 870-6011

USNRC REGION II  
ATLANTA, GEORGIA

83 JUN 29 09:22

Georgia Power  
Southern Company Services



D. O. Foster  
Vice President and General Manager  
Vogtle Project

June 24, 1983

United States Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region II - Suite 3100  
101 Marietta Street  
Atlanta, Georgia 30303

File: X7BG03-M38  
Log: GN-238

Reference: Vogtle Electric Generating Plant - Units 1 and 2  
50-424, 50-425; Pullman Power Products, Quality  
of Welds and Radiographs

Attention: Mr. James P. O'Reilly

Gentlemen:

Georgia Power Company had previously reported a potential deficiency to the NRC concerning the above referenced item. Georgia Power Company has completed its review of this concern and has determined that a reportable deficiency or substantial safety hazard does not exist.

A detailed engineering evaluation determined that the quality of welds was sufficient to withstand any potential accident or transient condition. Therefore, the condition of the as-received pipe spool could not have degraded any safety-related system.

This response contains no proprietary information and may be placed in the NRC Public Document Room upon receipt.

Yours truly,

*D. O. Foster*  
D. O. Foster

DOF/CWH/skr

xc: U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D. C. 20555

R. J. Kelly  
R. E. Conway  
G. F. Head  
J. T. Beckham, Jr.  
D. N. MacLemore  
D. E. Dutton  
W. F. Sanders

R. H. Pinson  
B. M. Guthrie  
R. A. Thomas  
J. A. Bailey  
O. Batum  
H. H. Gregory, III

E. D. Groover  
L. T. Gucwa  
M. Malcom  
G. Bockhold  
P. D. Rice  
J. L. Vota

OFFICIAL COPY

1022

8307120358 830624  
PDR ADOCK 05000424  
S PDR

1/0