

# BALTIMORE GAS AND ELECTRIC COMPANY

P.O. BOX 1475

BALTIMORE, MARYLAND 21203

DESIGNATED ORIGINAL

NUCLEAR POWER DEPARTMENT  
CALVERT CLIFFS NUCLEAR POWER PLANT  
LUSBY, MARYLAND 20657

Certified By Mal

May 27, 1983

Mr. James M. Allen  
Acting Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region 1  
631 Park Avenue  
King of Prussia, PA 19406

Docket No. 50-317  
License No. DPR 53

SUBJECT: LER 83-28/1T (U-1)

Dear Mr. Allen:

This letter is to confirm the verbal notification of your Mr. David Trimble of the inoperability of No. 11 and No. 12 ECCS Pump Room Air Coolers.

With No. 12 ECCS Pump Room Air Cooler already out of service for maintenance, No. 11 ECCS Pump Room Air Cooler was isolated from approximately 1900 on 5/24/83 to approximately 1715 on 5/25/83 in order to facilitate draining salt water from the piping in the vicinity of No. 12 ECCS Pump Room Air Cooler.

There is no direct Technical Specification requirement for these coolers to be operable. However, research is being conducted to determine whether these coolers are necessary to support operability of safety injection pumps and containment spray pumps under accident conditions.

A complete description of this event, together with cause and corrective actions will be provided in the follow up report.

Very truly yours,

*LBR*  
L. B. Russell  
Plant Superintendent

LER:RLW:mlk

cc: J. A. Tiernan  
Director, Office of Management  
Information and Program Control  
R. L. Wenderlich

R. M. Douglass  
L. B. Russell  
D. Trimble

8307120479 830527  
PDR ADDCK 05000317  
S PDR

1/0 IE 29