



# MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

June 24, 1983

JAMES P. MCGAUGHY, JR.  
VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 2900  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Special Report 83-050/0 -  
Floor Penetration CE-37G  
Opened  
AECM-83/0355

On May 19, 1983, floor penetration CE-37G in the Control Building upper cable room was opened to rework a cable tray hanger as part of Unit 2 construction activities. A fire watch was established in accordance with Technical Specification 3.7.7 from May 19 until the penetration was resealed on June 3. This Special Report is submitted pursuant to Technical Specification 6.9.2 as the seven (7) day Limiting Condition for Operation was exceeded.

Yours truly,

*James P. McGaughy, Jr.*  
FOR J. P. McGaughy, Jr.

JPM:sap

cc: Mr. J. B. Richard  
Mr. R. B. McGehee  
Mr. T. B. Conner  
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8307120526 830624  
PDR ADOCK 05000416  
S PDR

...amber Middle South Utilities System

OFFICIAL COPY

IE 22 1/0

USNRC REGION II  
ATLANTA, GEORGIA  
83 JUN 30 9:50