

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 ALJMF 2 00 - 000000 - 00 411111 4 5
7 8 9 14 15 25 26 30 37 CAT 38

CONT

01 REPORT SOURCE L 05000364 7 052883 8 062283 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 At 0030 on 5/28/83 during performance of FNP-2-STP-612.0 (Reactor Coolant Pump
03 Bus Reactor Trip Undervoltage Relay Calibration), 2A reactor coolant pump under-
04 voltage relay 27-3 was declared inoperable due to its out of Spec. condition (69.8
05 volts actual vs 75.43 volts required). Tech. Spec. 3.3.1 and 3.3.2, in part, re-
06 quires the relay to be operable. Tech. Spec. action statement requirements were
07 met. Health/safety of the public was not affected. A similar occurrence was re-
08 ported in LER 82-026/03L-0 (Unit 2).

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
1 A 11 E 12 A 13 R E L A Y X 14 D 15 Z 16
17 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
8 3 0 2 5 0 3 L 0
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER (26)
E 19 Z 19 Z 20 Z 21 0 0 0 0 N 23 Y 24 N 25 G 0 8 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 This event was attributed to setpoint drift. Following adjustment of the relay
11 setpoint, 2A reactor coolant pump undervoltage relay was declared operable at
12 0045 on 5/28/83.

13
14

15 FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)
E 28 1 0 0 29 NA B 31 Surveillance Test

16 ACTIVITY RELEASED CONTENT AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
Z 33 Z 34 NA NA

17 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)
0 0 0 37 Z 38 NA

18 PERSONNEL INJURIES NUMBER DESCRIPTION (41)
0 0 0 40 NA

19 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (43)
Z 42

20 PUBLICITY ISSUED DESCRIPTION (45)
N 44 NA

NAME OF PREPARER W. G. Hairston, III

PHONE (205) 899-5156

8307120590 830622
PDR ADOCK 05000348
S PDR

NRC USE ONLY