



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

July 27, 1983

JAMES P. MCGAUGHY, JR.
VICE PRESIDENT

USNRC REGION
ATLANTA, GEORGIA

83 JUL 29 49:00

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-059/0 - Fire
Rated Doors Blocked Open
During Planned PSW System
Outage
AECM-83/0420

On June 20, 1983, fire rated doors OC412 and OC712 to the RPS motor generator set rooms were blocked open to aid in room ventilation during a planned Plant Service Water System outage. Plant Service Water provides cooling to the plant chillers which in turn supplies cooling water to the air conditioning units for the rooms.

A fire watch was established in accordance with Technical Specification 3.7.7 and will continue until the doors are returned to service. This Special Report is submitted pursuant to Technical Specification 6.9.2 as the seven day time limit of Technical Specification 3.7.7 was exceeded. The expected restoration date is July 31, 1983.

Yours truly,

J.P. McGaughy
for J.P. McGaughy

JPM:sap

cc: Mr. J. B. Richard
Mr. R. B. McGehee

Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

ember Middle South Utilities System

8308030058 830727
PDR ADDCK 05000416
S PDR

OFFICIAL COPY

IE 22
1/0