



**Consumers
Power
Company**

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-0774

J A Mooney
Executive Manager
Midland Project Office

PRINCIPAL STAFF			
✓ RA	SCS	ENF	
D/RA	PAO	SCS	3
A/RA	PAO		0
DPRP	SLO		
DRMA	RC		
DRMSP			
DE			
ML			
OL	FILE		

July 27, 1983

Mr J J Harrison
Midland Project Section
U S Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

MIDLAND ENERGY CENTER GWO 7020
REMEDIAL SOILS CONCRETE MIX
File: 0485.16 UFI: 42*05*22*04 Serial: CSC-6815
70*01

This letter summarizes the telephone conversation 7/26/83, between Dr. R. Landsman of NRC Region III, R. Wieland and K. Razdan of CPCo, and I. Jha, V. Patankar, and M. DasGupta, of Bechtel Project Engineering. Three new concrete mix designs have been developed for addition to Spec C-230 for use in the underpinning work. After discussing the proportioning and qualification of mixes C-6C-H and E-5C-H (with superplasticizer) and mix E-5C (without superplasticizer), Dr. Landsman concurred with CPCo's use of these for the underpinning work.

JAM

JAM/RHW/klm