

ATTACHMENT TO LER 83-043
SOUTHERN CALIFORNIA EDISON COMPANY
SAN ONOFRE NUCLEAR GENERATING STATION
UNIT NO. 3, DOCKET NO. 50-362

SUPPLEMENTAL INFORMATION FOR EVENT DESCRIPTION AND PROBABLE
CONSEQUENCES:

Therefore, LCO 3.0.3 was invoked at 1350. The chiller was declared operable at 1422 and LCO 3.0.3 was exited. Public health and safety were not affected. See also Unit 2 LER No. 83-049.

SUPPLEMENTAL INFORMATION FOR CAUSE DESCRIPTION AND CORRECTIVE
ACTIONS:

At the conclusion of this investigation, an update to this LER will be issued.

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

RECEIVED
NRC

SCE

1983 JUL 28 PM 12:12

REGION VINE

TELEPHONE
(714) 492-7700

H. B. RAY

STATION MANAGER

July 25, 1983

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket No. 50-362
14-Day Follow-Up Report
Licensee Event Report No. 83-043
San Onofre Nuclear Generating Station, Unit 3


Reference: Letter, H.B. Ray (SCE) to J.B. Martin (NRC), dated
July 11, 1983

The referenced letter provided you with confirmation of our prompt notification, pursuant to Section 6.9.1.12.b of Appendix A, Technical Specifications to Facility Operating License NPF-15 for San Onofre Unit 3, of an event involving the loss of Train B Emergency Chiller E-335.

Pursuant to Section 6.9.1.12.b, this submittal provides the required 14-day follow-up report and a copy of Licensee Event Report (LER) No. 83-043 to address this event.

If there are any questions regarding this event, please contact me.

Sincerely,



Enclosure: LER 83-043

IE-22

Mr. J.B. Martin

-2-

July 25, 1983

cc: A.E. Chaffee (USNRC Resident Inspector, Units 2 and 3)
J.P. Stewart (USNRC Resident Inspector, Units 2 and 3)

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement

U.S. Nuclear Regulatory Commission
Division of Technical Information and Document Control

Institute of Nuclear Power Operations (INPO)