

CONTROL BLOCK

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 N C M G S 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

CONT

01 REPORT SOURCE L 0 5 0 0 0 3 7 0 0 6 2 7 8 3 0 7 2 7 8 3  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES

02 On 6/21/83 and 6/27/83, during a tech. spec. surveillance compliance review con-  
03 ducted as a result of several recently discovered missed surveillances (ref. RO-  
04 370/83-22), two overcurrent protective device surveillance item deficiencies were  
05 identified (breakers SMXG-R5A: pressurizer heaters 28, 55, and 56; and 2MXM-R6D:  
06 175 ton polar crane feeder). These omissions from the 10% sample functional test  
07 violate T.S.4.8.4.1.a which is reportable per T.S.6.9.1.11(b). The two breakers  
08 were tested and were found satisfactory. Health and safety of the public were  
09 unaffected.

09 SYSTEM CODE E G 10 CAUSE CODE X 11 CAUSE SUBCODE Z 12 COMPONENT CODE Z Z Z Z Z Z 13 COMP SUBCODE Z 14 VALVE SUBCODE Z 15  
17 LER NO REPORT NUMBER 8 3 18 EVENT YEAR 8 3 19 SEQUENTIAL REPORT NO. 0 3 1 20 OCCURRENCE CODE 0 3 21 REPORT TYPE L 22 REVISION NO. 0  
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NRC-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER  
18 G 19 Z 20 Z 21 Z 22 0 0 0 0 23 N 24 N 25 Z 26 Z 9 9 9

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS

10 The two breakers were listed in the McGuire Units 1 and 2 combined tech. specs.,  
11 but had not been incorporated into the 18 month surveillance procedure. The pro-  
12 cedure had been written based on the existing Unit 1 only tech. specs. require-  
13 ments (which did not list the 2 breakers). Reviews of draft copies of the Unit 1  
14 and 2 tech. specs. failed to identify the breaker discrepancy. The procedure was  
15 revised to include the 2 breakers.

15 FACILITY STATUS X 28 POWER 0 0 0 29 OTHER STATUS 30 Main. Outage 31 METHOD OF DISCOVERY C 32 DISCOVERY DESCRIPTION 32 Procedure Review

16 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36  
16 Z 33 Z 34 N/A 35 N/A 36

17 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39  
17 0 0 0 37 Z 38 N/A 39

18 PERSONNEL INJURIES NUMBER DESCRIPTION 41  
18 0 0 0 40 N/A 41

19 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43  
19 Z 42 N/A 43

20 PUBLICITY ISSUED DESCRIPTION 45  
20 N 44 N/A 45

NAME OF PREPARER Phillip B. Nardoci

PHONE (704) 373-7432

**DUKE POWER COMPANY**

P.O. BOX 33189  
CHARLOTTE, N.C. 28242

HAL B. TUCKER  
VICE PRESIDENT  
NUCLEAR PRODUCTION

July 27, 1983

USNRC REGION II  
ATLANTA, GEORGIA  
TELEPHONE  
(704) 373-4531

83 AUG 3 10:13

Mr. James P. O'Reilly, Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street NW, Suite 2900  
Atlanta, Georgia 30303

Subject: McGuire Nuclear Station Unit 2  
Docket No. 50-370  
LER/RO-370/83-31

Dear Mr. O'Reilly:

Please find attached Reportable Occurrence Report RO-370/83-31. This report concerns T.S. 3.8.4.1, "All containment penetration conductor overcurrent protective devices shown in Table 3.8-1 shall be operable". This incident was considered to be of no significance with respect to the health and safety of the public.

Very truly yours,

*H.B. Tucker /H*

Hal B. Tucker

PBN:jfw  
Attachment

cc: Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Records Center  
Institute of Nuclear Power Operations  
1100 Circle 75 Parkway, Suite 1500  
Atlanta, Georgia 30339

Mr. W. T. Orders  
NRC Resident Inspector  
McGuire Nuclear Station

OFFICIAL COPY

IE22

1/1